



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 18, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240405

Property Address: 2902 E PIONEER, BUILDING H, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING H 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER - ETC – APT BLDG H

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Maintain corrections below.

Corrections:

- 1 - Maintain concrete washout. No pumping into storm, sewer, or on the ground.
- Maintain asphalt cleanliness.
- Maintain garbage pick up.
- Zero track out on city streets.
- Protect the infiltration area along the south side of the building. No equipment in this area.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387