### City of Puyallup



## **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165

www.cityofpuyallup.org

### INSPECTION REPORT

Date of Inspection: Dec 24, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRCCP20221569

**Property Address:** 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT

NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

**To construct:** Extend utilities from 10th street SE on a site for purposes of construction

2- 6 plexus as well as provide infiltration on site. COPPERBERRY

**CONDOMINIUMS** 

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 12/19 - JL - Met Jamie on site for a quick visit about the frontage and easement.

Note: There is paint washout in the storm filter.

12/23 - JL - See corrections below.

### **Corrections:**

#### 1 STREETS

- Asphalt frontage improvements. Includes re-striping 1 month after paving.
- Street light j-box (3ea) need welded.
- Street light base needs grout.
- South neighboring property driveway needs cut, paved, extruded curb installed. (Match existing) White painted line for saw cut and removal.
- South neighboring property sidewalk needs backfilled.

### 2 STORM

- Finish down spout tie in on South and north building.
- Stabilize exposed soil slope at south end of wall.
- Re-grade slope at step of wall. (Middle) No soil drifting over top of wall.
- Finish landscape around north building.
- Stabilize exposed soil slope at north end of wall.
- Pour concrete collar around existing storm MH in NW corner.
- Clean garbage debris off on site parking lot.

# CATTOF PUVALLES

### City of Puyallup

### **Engineering Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

### 3 SEWER

- North building side sewer's need to be cut down and sewer Carson boxes installed.
- 4 MISC.
  - Sidewalks around north building needs to be finished, including walkway to city right of way.
  - SWA
  - As-Builts
  - Engineer Letter
  - Need fire double check certified.
  - Need fire service meter tagged "FOR FIRE ONLY".
  - Finish fire inspection card and WSP form.

### Sincerely,

THAT I SHOW THE SHOW

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 244-0387