



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 31, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240139

Property Address: 2902 E PIONEER - BUILDING B, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - 2902 E PIONEER - ETC – APT BLDG B

On this day we have inspected your construction for **Sidewer Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Connection made at the sampling tee on the east side of the building. eccentric reducer , 45, 5' pipe, leveling 45, and 15' of pipe to reach the inside of the building. good to backfill. Pea gravel bedded in spots. I let the crew know to use CSTC for bedding. good to backfill

Corrections:

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov
(253) 204-5633