



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 03, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20240139

Property Address: 2902 E PIONEER - BUILDING B, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - 2902 E PIONEER - ETC – APT BLDG B

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Prior to building "C" E&S inspection please cover the concrete wash out bin that has been used.

This can easily be accomplished with 2-3 2x4's laid across the bin, plastic over that, and sand bags set of the 2x4"s.

Thank you

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387