



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 06, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCNC20241019

**Property Address:** 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

**Contractor:** MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA 98409

**To construct:** Construct Early Learning Center

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Maintain corrections.

Note: PRDE20241467 (DEMO PERMIT) has been closed.

**Corrections:**

- 1 - Please backfill interior silt fence, where swale and drain was, with native material.
- Maintain silt fence.
- Zero track out.
- Maintain CB socks.
- No silt runoff into ROW ditch.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little  
Development Engineering Inspector  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 244-0387