



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 06, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRFUP20241442

**Property Address:** 113 23RD AVE SE, PUYALLUP, WA 98372;

**Contractor:** MASTEC NORTH AMERICA INC 806 Douglas Rd #1100 Coral Gables, FL 33134

**To construct:** JB0001878687 Phase 4 - Comcast proposes to transfer (E) .625 coax cable to pole

On this day we have inspected your construction for **Job Start Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** I drove by at 8:15 a.m and at 9:45 a.m. and did not see a crew on site. When I called, the contractor said the crew was heading to the job at 1:30pm. They performed pole transfers on 23rd Ave SE, 5th ST SE then moved to 20th AVE SE. Washington Traffic Control set signs. The foreman said that all other poles on the permit had been transferred.

NOTE: I didn't see them transfer facilities on 23rd but they swept the riser to the new pole rather than moving it. The aerial foreman said it was a temporary fix until the underground crew can move it.

**Corrections:**

- 1 Riser was swept to the new pole and conduit is broken. It needs to be excavated and moved to the brace.

Sincerely,

Cheryl Trimble

Development Engineering Inspector

CTrimble@PuyallupWA.gov



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 290-9834