



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 07, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20241601

**Property Address:** 401 15TH AVE SE, PUYALLUP, WA 98372;

**Contractor:** M BROWN INDUSTRIES LLC - NW CEILING 18389 S NORMAN RD.  
OREGON CITY, OR 97045 (971) 645-1919

**To construct:** Removing existing patient lift and installing new support system, rails  
and patient lift in Room 28 in the Rehab unit

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** remove rivets from and complete berc. clips at 2 walls as discussed with contractor.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684