



SMITH FIRE SYSTEMS, INC
 1106 54TH AVENUE EAST TACOMA, WASHINGTON 98424
 (253) 926-1880 Fax (253) 926-2350
 CONTR. REG. NO. SMITHFS1360T

GENERAL / HYDRAULIC CALCULATION INFORMATION SHEET

PROJECT NAME:	WASHINGTON STATE FAIR	JOB NO.:	TI24073	OWNER: WA STATE FAIR AHJ: CITY OF PUYALLUP
	INTERNATIONAL VILLAGE	DATE:	11/25/2024	
ADDRESS:	110 9TH AVE SW	BY:	A. RIDEOUT	
	PUYALLUP, WA 98371			

SYSTEM DESIGNATION: **SYSTEM #1- GROUND FLOOR** DESIGN PER: **NFPA #13 (2019 EDITION)**
 OCCUPANCY CLASSIFICATION: **ORDINARY HAZARD - GROUP I**

DESIGN CRITERIA:		SPRINKLER MANUFACTURER:	RELIABLE
NFPA SECTION:	19.3.3.2.3.1	K-FACTOR:	5.6
QUICK RESPONSE REDUCTION:	NO	MODEL:	F1FR56
NFPA SECTION:	19.3.3.2.4	TEMPERATURE:	286°
SLOPED CEILING INCREASE:	NO	RESPONSE TYPE:	QR
NFPA SECTION:	20.13.3		
DRY SYSTEM INCREASE:	YES 30% AREA INCREASE	TOTAL SPRINKLERS CALCULATED:	24
		MAX AREA OF COVERAGE PER SPRINKLER:	130 SQ. FT
		MAX DISTANCE BETWEEN SPRINKLERS:	15
SYSTEM TYPE:	DRY	FIRE PUMP:	NO
MAX CEILING HEIGHT:	N/A	RATED CAPACITY OF PUMP:	N/A
CEILING HEIGHT:	N/A		
ROOF SLOPE:	N/A		

DESIGN AREA

0.15 GPM OVER THE MOST HYDRAULICALLY DEMANDING **1950** SQ. FT.

ALLOWANCES INCLUDED IN CALCULATIONS: **OUTSIDE HOSE 250 GPM** ADDED AT: **CONNECTION TO SOURCE**

WATER SUPPLY:	ELEVATION OF TEST: 0 FT.	ELEVATION OF LEVEL 1: 0 FT.	MAIN DRAIN TEST:
STATIC	59 PSI	DATE OF TEST: 11/19/2024	S: R:
RESIDUAL	20 PSI	DATA PROVIDED BY: CITY OF PUYALLUP	INSPECTORS TEST:
FLOW	1560 GPM	LOCATION OF TEST: 110 9TH AVE SW, PUYALLUP WA 98371	TRIP TIME:

DRY SYSTEM NUMBER 1		
AREA	SQ. FT.	SPRINKLERS
MAIN FLOOR	14,542	164
ROOF TOP	10,321	31
TOTAL:	24,863	195

NOTES:

MOST DEMANDING AREA: SYS. 1
 DENSITY: **.15** GPM OVER **1950** SQUARE FEET
BASE OF RISER: **472.2** GPM REQUIRED AT 40.6 PSI
SUMMARY: **722.2** GPM REQUIRED AT 47.1 PSI
 AT CONNECTION TO **SOURCE**
 (INCLUDING **250** GPM FOR HOSE STREAMS)
 DRY SYSTEM VOLUME: 660 GALLONS

Expires 12/31/25

**WASHINGTON STATE
 CERTIFICATE OF COMPETENCY
 FIRE SPRINKLER SYSTEMS**

Nicholas James Scott
 0627-1019-C Level 3
 Smith Fire Systems, Inc.
 SMITHFS1360T

Nicholas James Scott 01/07/2025
 Signature Date



SMITH FIRE SYSTEMS, INC.

WATER SUPPLY DATA

STATIC _____ 59 _____ PSI
RESIDUAL _____ 20 _____ PSI
FLOWING _____ 1560 _____ GPM

JOB NAME WASHINGTON STATE FAIR - INTERNATIONAL VILLAGE

ADDRESS 110 9TH AVE SW

DATE PUYALLUP, WA 98371

JOB NO. TI24073

SYSTEM/AREA #1 - ENTIRE


MOST DEMANDING AREA: SYS. 1

DENSITY: .15 GPM OVER 1950 SQUARE FEET

BASE OF RISER: 472.2 GPM REQUIRED AT 40.6 PSI

SUMMARY: 722.2 GPM REQUIRED AT 47.1 PSI

**AT CONNECTION TO SOURCE
(INCLUDING 250 GPM FOR HOSE STREAMS)**



DATE: 12/27/2024 NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF
 JOB TITLE: SYS 1

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	59.0	20.0	1560.0	49.6	722.2	47.1

Available pressure is 2.5 psi (5%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	722.2 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	250.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	472.2 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)	AREA (FT^2)	DENSITY	
						REQ. (GPM/FT^2)	ACT. (GPM/FT^2)
S1	9.5	K= 5.60	9.3	17.1	100.0	0.150	0.171
S2	9.5	K= 5.60	9.3	17.1	100.0	0.150	0.171
S3	9.5	K= 5.60	9.4	17.1	80.0	0.150	0.214
S4	9.5	K= 5.60	9.0	16.8	80.0	0.150	0.210
S5	9.5	K= 5.60	9.3	17.1	50.0	0.150	0.341
S6	9.5	K= 5.60	9.4	17.1	50.0	0.150	0.343
S7	9.5	K= 5.60	8.9	16.7	80.0	0.150	0.209
S8	9.5	K= 5.60	9.4	17.2	64.0	0.150	0.269
S9	9.5	K= 5.60	9.5	17.3	72.0	0.150	0.240
S10	9.5	K= 5.60	9.3	17.0	104.0	0.150	0.164
S11	9.5	K= 5.60	9.6	17.3	104.0	0.150	0.167
S12	9.5	K= 5.60	9.7	17.4	116.0	0.150	0.150
S13	12.8	K= 5.60	16.7	22.9	116.0	0.100	0.197
S14	12.8	K= 5.60	16.8	22.9	116.0	0.100	0.198
S15	12.8	K= 5.60	17.0	23.1	116.0	0.100	0.199
S16	12.8	K= 5.60	16.7	22.9	84.0	0.100	0.273
S17	12.8	K= 5.60	16.8	22.9	84.0	0.100	0.273
S18	12.8	K= 5.60	17.0	23.1	84.0	0.100	0.275
S19	18.5	K= 5.60	14.6	21.4	116.0	0.100	0.184
S20	18.5	K= 5.60	14.6	21.4	116.0	0.100	0.185
S21	18.4	K= 5.60	14.9	21.6	116.0	0.100	0.186
S22	18.5	K= 5.60	14.7	21.5	84.0	0.100	0.255
S23	18.5	K= 5.60	14.7	21.5	84.0	0.100	0.256
S24	18.4	K= 5.60	15.0	21.7	84.0	0.100	0.258
1	13.6	- - - -	12.4	- - -	- - -	- - -	- - -
2	13.6	- - - -	12.5	- - -	- - -	- - -	- - -
3	13.5	- - - -	12.6	- - -	- - -	- - -	- - -
4	13.6	- - - -	12.4	- - -	- - -	- - -	- - -
5	13.6	- - - -	12.4	- - -	- - -	- - -	- - -
6	13.5	- - - -	12.6	- - -	- - -	- - -	- - -
7	13.6	- - - -	12.6	- - -	- - -	- - -	- - -
8	13.6	- - - -	12.7	- - -	- - -	- - -	- - -
9	13.5	- - - -	12.8	- - -	- - -	- - -	- - -

DATE: 12/27/2024 \NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF

JOB TITLE: SYS 1

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)	AREA (FT^2)	DENSITY	
						REQ. (GPM/FT^2)	ACT.
10	13.6	- - - -	12.8	- - -	- - -	- - -	- - -
11	13.6	- - - -	12.9	- - -	- - -	- - -	- - -
12	13.5	- - - -	13.0	- - -	- - -	- - -	- - -
M1	12.0	- - - -	13.8	- - -	- - -	- - -	- - -
M2	13.6	- - - -	12.7	- - -	- - -	- - -	- - -
M3	12.0	- - - -	13.8	- - -	- - -	- - -	- - -
M4	13.6	- - - -	12.8	- - -	- - -	- - -	- - -
M5	12.0	- - - -	14.0	- - -	- - -	- - -	- - -
M6	13.6	- - - -	13.0	- - -	- - -	- - -	- - -
M7	12.0	- - - -	14.3	- - -	- - -	- - -	- - -
M8	13.6	- - - -	13.2	- - -	- - -	- - -	- - -
M9	12.0	- - - -	14.4	- - -	- - -	- - -	- - -
M10	18.5	- - - -	13.6	- - -	- - -	- - -	- - -
M11	16.4	- - - -	17.2	- - -	- - -	- - -	- - -
M12	18.4	- - - -	15.0	- - -	- - -	- - -	- - -
M13	11.5	- - - -	18.6	- - -	- - -	- - -	- - -
M14	13.4	- - - -	17.1	- - -	- - -	- - -	- - -
M15	11.4	- - - -	18.6	- - -	- - -	- - -	- - -
M16	13.4	- - - -	17.1	- - -	- - -	- - -	- - -
M17	11.5	- - - -	18.6	- - -	- - -	- - -	- - -
M18	16.5	- - - -	16.6	- - -	- - -	- - -	- - -
M19	16.4	- - - -	16.6	- - -	- - -	- - -	- - -
M20	18.4	- - - -	15.2	- - -	- - -	- - -	- - -
M21	16.4	- - - -	16.7	- - -	- - -	- - -	- - -
M22	18.4	- - - -	15.3	- - -	- - -	- - -	- - -
M23	15.5	- - - -	22.2	- - -	- - -	- - -	- - -
M24	16.3	- - - -	20.9	- - -	- - -	- - -	- - -
TOR	15.3	- - - -	30.8	- - -	- - -	- - -	- - -
BOR	1.5	- - - -	40.6	- - -	- - -	- - -	- - -
FLG	0.5	- - - -	41.1	- - -	- - -	- - -	- - -
BFP1	0.0	- - - -	42.3	- - -	- - -	- - -	- - -
BFP2	0.0	- - - -	46.3	- - -	- - -	- - -	- - -
SOURCE	0.0	SOURCE	47.1	472.2	- - -	- - -	- - -

DATE: 12/27/2024 NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF
 JOB TITLE: SYS 1

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.	
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.	(PSI)
	Pipe: 1					17.1	1.049 PL	27.00	PF	4.9
1	13.6	0.0	12.4	0.0	6.3	100 FTG	4ET	PE	1.8	
S1	9.5	5.6	9.3	17.1		0.136 TL	36.20	PV		
	Pipe: 2					17.1	1.049 PL	27.00	PF	4.9
2	13.6	0.0	12.5	0.0	6.3	100 FTG	4ET	PE	1.8	
S2	9.5	5.6	9.3	17.1		0.136 TL	36.20	PV		
	Pipe: 3					17.1	1.049 PL	27.00	PF	5.0
3	13.5	0.0	12.6	0.0	6.4	100 FTG	4ET	PE	1.7	
S3	9.5	5.6	9.4	17.1		0.137 TL	36.20	PV		
	Pipe: 4					16.8	1.049 PL	29.00	PF	5.2
4	13.6	0.0	12.4	0.0	6.2	100 FTG	5ET	PE	1.8	
S4	9.5	5.6	9.0	16.8		0.132 TL	39.60	PV		
	Pipe: 5					17.1	1.049 PL	27.00	PF	4.9
5	13.6	0.0	12.4	0.0	6.3	100 FTG	4ET	PE	1.8	
S5	9.5	5.6	9.3	17.1		0.136 TL	36.20	PV		
	Pipe: 6					17.1	1.049 PL	27.00	PF	5.0
6	13.5	0.0	12.6	0.0	6.4	100 FTG	4ET	PE	1.7	
S6	9.5	5.6	9.4	17.1		0.137 TL	36.20	PV		
	Pipe: 7					16.7	1.049 PL	31.00	PF	5.5
7	13.6	0.0	12.6	0.0	6.2	100 FTG	5ET	PE	1.8	
S7	9.5	5.6	8.9	16.7		0.131 TL	41.60	PV		
	Pipe: 8					17.2	1.049 PL	27.00	PF	5.0
8	13.6	0.0	12.7	0.0	6.4	100 FTG	4ET	PE	1.8	
S8	9.5	5.6	9.4	17.2		0.138 TL	36.20	PV		
	Pipe: 9					17.3	1.049 PL	27.00	PF	5.0
9	13.5	0.0	12.8	0.0	6.4	100 FTG	4ET	PE	1.7	
S9	9.5	5.6	9.5	17.3		0.139 TL	36.20	PV		
	Pipe: 10					17.0	1.049 PL	29.00	PF	5.4
10	13.6	0.0	12.8	0.0	6.3	100 FTG	5ET	PE	1.8	
S10	9.5	5.6	9.3	17.0		0.135 TL	39.60	PV		
	Pipe: 11					17.3	1.049 PL	27.00	PF	5.1
11	13.6	0.0	12.9	0.0	6.4	100 FTG	4ET	PE	1.8	
S11	9.5	5.6	9.6	17.3		0.140 TL	36.20	PV		
	Pipe: 12					17.4	1.049 PL	27.00	PF	5.1
12	13.5	0.0	13.0	0.0	6.5	100 FTG	4ET	PE	1.7	
S12	9.5	5.6	9.7	17.4		0.141 TL	36.20	PV		
	Pipe: B1					-17.1	2.185 PL	10.00	PF	0.0
1	13.6	0.0	12.4	0.0	1.5	100 FTG	----	PE	0.0	
2	13.6	0.0	12.5	0.0		0.004 TL	10.00	PV		

DATE: 12/27/2024 NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF
 JOB TITLE: SYS 1

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	VEL (FPS)	DIA (IN)	HW (C)	LENGTH	PRESS.	SUM.
	NODES	(FT)	(K)	(PSI)	(GPM)			FL/FT		(FT)	(PSI)	(PSI)
	Pipe: B2					-34.1		2.185	PL	8.00	PF	0.1
2		13.6	0.0	12.5	0.0	2.9		100	FTG	----	PE	0.0
3		13.5	0.0	12.6	0.0			0.014	TL	8.00	PV	
	Pipe: B3					-51.3		2.185	PL	2.00	PF	0.2
3		13.5	0.0	12.6	0.0	4.4		100	FTG	E	PE	-0.0
M2		13.6	0.0	12.7	0.0			0.029	TL	5.30	PV	
	Pipe: B4					-16.8		2.185	PL	8.00	PF	0.0
4		13.6	0.0	12.4	0.0	1.4		100	FTG	----	PE	0.0
5		13.6	0.0	12.4	0.0			0.004	TL	8.00	PV	
	Pipe: B5					-33.8		2.185	PL	8.00	PF	0.1
5		13.6	0.0	12.4	0.0	2.9		100	FTG	----	PE	0.0
6		13.5	0.0	12.6	0.0			0.014	TL	8.00	PV	
	Pipe: B6					-51.0		2.185	PL	4.00	PF	0.2
6		13.5	0.0	12.6	0.0	4.4		100	FTG	E	PE	-0.0
M4		13.6	0.0	12.8	0.0			0.029	TL	7.30	PV	
	Pipe: B7					-16.7		2.185	PL	8.00	PF	0.0
7		13.6	0.0	12.6	0.0	1.4		100	FTG	----	PE	0.0
8		13.6	0.0	12.7	0.0			0.004	TL	8.00	PV	
	Pipe: B8					-33.9		2.185	PL	8.00	PF	0.1
8		13.6	0.0	12.7	0.0	2.9		100	FTG	----	PE	0.0
9		13.5	0.0	12.8	0.0			0.014	TL	8.00	PV	
	Pipe: B9					-51.2		2.185	PL	4.00	PF	0.2
9		13.5	0.0	12.8	0.0	4.4		100	FTG	E	PE	-0.0
M6		13.6	0.0	13.0	0.0			0.029	TL	7.30	PV	
	Pipe: B10					-17.0		2.185	PL	8.00	PF	0.0
10		13.6	0.0	12.8	0.0	1.5		100	FTG	----	PE	0.0
11		13.6	0.0	12.9	0.0			0.004	TL	8.00	PV	
	Pipe: B11					-34.4		2.185	PL	8.00	PF	0.1
11		13.6	0.0	12.9	0.0	2.9		100	FTG	----	PE	0.0
12		13.5	0.0	13.0	0.0			0.014	TL	8.00	PV	
	Pipe: B12					-51.8		2.185	PL	4.00	PF	0.2
12		13.5	0.0	13.0	0.0	4.4		100	FTG	E	PE	-0.0
M8		13.6	0.0	13.2	0.0			0.030	TL	7.30	PV	
	Pipe: B13					-22.9		2.185	PL	10.50	PF	0.1
S13		12.8	5.6	16.7	22.9	2.0		100	FTG	----	PE	0.0
S14		12.8	5.6	16.8	22.9			0.007	TL	10.50	PV	
	Pipe: B14					-45.8		2.185	PL	10.50	PF	0.2
S14		12.8	5.6	16.8	22.9	3.9		100	FTG	----	PE	0.0
S15		12.8	5.6	17.0	23.1			0.024	TL	10.50	PV	

DATE: 12/27/2024 \NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF

JOB TITLE: SYS 1

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	VEL (FPS)	DIA (IN)	HW (C)	LENGTH	PRESS.	SUM.
NODES	(FT)	(K)	(PSI)	(GPM)				FL/FT		(FT)	(PSI)	(PSI)
Pipe: B15												
S15	12.8	5.6	17.0	23.1	5.9	-68.9	5.9	2.185	100	3.58	PF	0.3
M14	13.4	0.0	17.1	0.0				0.050	100	6.88	PE	-0.3
Pipe: B16												
S16	12.8	5.6	16.7	22.9	2.0	-22.9	2.0	2.185	100	10.50	PF	0.1
S17	12.8	5.6	16.8	22.9				0.007	100	10.50	PE	0.0
Pipe: B17												
S17	12.8	5.6	16.8	22.9	3.9	-45.8	3.9	2.185	100	10.50	PF	0.2
S18	12.8	5.6	17.0	23.1				0.024	100	10.50	PE	0.0
Pipe: B18												
S18	12.8	5.6	17.0	23.1	5.9	-68.9	5.9	2.185	100	3.58	PF	0.3
M16	13.4	0.0	17.1	0.0				0.050	100	6.88	PE	-0.3
Pipe: B19												
S19	18.5	5.6	14.6	21.4	1.8	-21.4	1.8	2.185	100	10.50	PF	0.1
S20	18.5	5.6	14.6	21.4				0.006	100	10.50	PE	0.0
Pipe: B20												
S20	18.5	5.6	14.6	21.4	3.7	-42.8	3.7	2.185	100	10.50	PF	0.2
S21	18.4	5.6	14.9	21.6				0.021	100	10.50	PE	0.0
Pipe: B21												
S21	18.4	5.6	14.9	21.6	5.5	-64.4	5.5	2.185	100	3.58	PF	0.3
M20	18.4	0.0	15.2	0.0				0.045	100	6.88	PE	-0.0
Pipe: B22												
S22	18.5	5.6	14.7	21.5	1.8	-21.5	1.8	2.185	100	10.50	PF	0.1
S23	18.5	5.6	14.7	21.5				0.006	100	10.50	PE	0.0
Pipe: B23												
S23	18.5	5.6	14.7	21.5	3.7	-42.9	3.7	2.185	100	10.50	PF	0.2
S24	18.4	5.6	15.0	21.7				0.021	100	10.50	PE	0.0
Pipe: B24												
S24	18.4	5.6	15.0	21.7	5.5	-64.6	5.5	2.185	100	3.58	PF	0.3
M22	18.4	0.0	15.3	0.0				0.045	100	6.88	PE	-0.0
Pipe: R1												
M1	12.0	0.0	13.8	0.0	4.4	51.3	4.4	2.185	100	1.58	PF	0.4
M2	13.6	0.0	12.7	0.0				0.029	100	12.38	PE	-0.7
Pipe: R2												
M3	12.0	0.0	13.8	0.0	4.4	51.0	4.4	2.185	100	1.58	PF	0.4
M4	13.6	0.0	12.8	0.0				0.029	100	12.38	PE	-0.7
Pipe: R3												
M5	12.0	0.0	14.0	0.0	4.4	51.2	4.4	2.185	100	1.58	PF	0.4
M6	13.6	0.0	13.0	0.0				0.029	100	12.38	PE	-0.7

DATE: 12/27/2024\NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF

JOB TITLE: SYS 1

PIPE TAG	Q (GPM)	DIA (IN)	LENGTH	PRESS.
END ELEV. NOZ. PT DISC. VEL (FPS) HW (C) FL/FT			(FT)	SUM. (PSI)
NODES (FT) (K) (PSI) (GPM)				
Pipe: R4	51.8	2.185	1.58	PF 0.4
M7 12.0 0.0 14.3 0.0 4.4 100 FTG T				PE -0.7
M8 13.6 0.0 13.2 0.0 0.030 TL 12.38				PV
Pipe: R5	-205.2	3.314	6.58	PF 2.0
M9 12.0 0.0 14.4 0.0 7.6 100 FTG 3ET				PE -2.8
M10 18.5 0.0 13.6 0.0 0.050 TL 40.28				PV
Pipe: R6	205.2	3.314	2.00	PF 1.3
M11 16.4 0.0 17.2 0.0 7.6 100 FTG ET				PE -0.9
M12 18.4 0.0 15.0 0.0 0.050 TL 25.30				PV
Pipe: R7	68.9	2.185	1.92	PF 0.6
M13 11.5 0.0 18.6 0.0 5.9 100 FTG T				PE -0.8
M14 13.4 0.0 17.1 0.0 0.050 TL 12.72				PV
Pipe: R8	68.9	2.185	2.00	PF 0.6
M15 11.4 0.0 18.6 0.0 5.9 100 FTG T				PE -0.9
M16 13.4 0.0 17.1 0.0 0.050 TL 12.80				PV
Pipe: R9	-137.9	4.298	5.00	PF 0.1
M17 11.5 0.0 18.6 0.0 3.0 100 FTG 2E				PE -2.2
M18 16.5 0.0 16.6 0.0 0.007 TL 18.20				PV
Pipe: R10	64.4	2.185	2.00	PF 0.6
M19 16.4 0.0 16.6 0.0 5.5 100 FTG T				PE -0.9
M20 18.4 0.0 15.2 0.0 0.045 TL 12.80				PV
Pipe: R11	64.6	2.185	2.00	PF 0.6
M21 16.4 0.0 16.7 0.0 5.5 100 FTG T				PE -0.9
M22 18.4 0.0 15.3 0.0 0.045 TL 12.80				PV
Pipe: R12	472.1	4.298	0.83	PF 0.9
M23 15.5 0.0 22.2 0.0 10.4 100 FTG 2E				PE -0.4
M24 16.3 0.0 20.9 0.0 0.066 TL 14.03				PV
Pipe: M1	-51.3	3.314	8.00	PF 0.0
M1 12.0 0.0 13.8 0.0 1.9 100 FTG ----				PE 0.0
M3 12.0 0.0 13.8 0.0 0.004 TL 8.00				PV
Pipe: M2	-102.3	3.314	16.00	PF 0.2
M3 12.0 0.0 13.8 0.0 3.8 100 FTG ----				PE 0.0
M5 12.0 0.0 14.0 0.0 0.014 TL 16.00				PV
Pipe: M3	-153.5	3.314	8.00	PF 0.2
M5 12.0 0.0 14.0 0.0 5.7 100 FTG ----				PE 0.0
M7 12.0 0.0 14.3 0.0 0.029 TL 8.00				PV
Pipe: M5	-205.2	3.314	2.00	PF 0.1
M7 12.0 0.0 14.3 0.0 7.6 100 FTG ----				PE 0.0
M9 12.0 0.0 14.4 0.0 0.050 TL 2.00				PV

DATE: 12/27/2024 \NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF
 JOB TITLE: SYS 1

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.
									(PSI)
Pipe: M8									
M10	18.5	0.0	13.6	0.0	7.6	3.314	100	28.83	PF 1.4
M12	18.4	0.0	15.0	0.0		0.050	TL	28.83	PV 0.0
Pipe: M9									
M13	11.5	0.0	18.6	0.0	1.5	4.298	100	8.00	PF 0.0
M15	11.4	0.0	18.6	0.0		0.002	TL	8.00	PE 0.0
Pipe: M10									
M15	11.4	0.0	18.6	0.0	3.0	4.298	100	5.33	PF 0.0
M17	11.5	0.0	18.6	0.0		0.007	TL	5.33	PE -0.0
Pipe: M11									
M18	16.5	0.0	16.6	0.0	3.0	4.298	100	2.67	PF 0.0
M19	16.4	0.0	16.6	0.0		0.007	TL	2.67	PE 0.0
Pipe: M12									
M19	16.4	0.0	16.6	0.0	4.5	4.298	100	8.00	PF 0.1
M21	16.4	0.0	16.7	0.0		0.014	TL	8.00	PE 0.0
Pipe: M13									
M21	16.4	0.0	16.7	0.0	5.9	4.298	100	18.25	PF 0.4
M11	16.4	0.0	17.2	0.0		0.023	TL	18.25	PE 0.0
Pipe: M14									
M11	16.4	0.0	17.2	0.0	10.4	4.298	100	49.83	PF 3.7
M24	16.3	0.0	20.9	0.0		0.066	TL	56.43	PE 0.0
Pipe: M15									
M23	15.5	0.0	22.2	0.0	10.4	4.298	100	93.83	PF 8.5
TOR	15.3	0.0	30.8	0.0		0.066	TL	129.73	PE 0.1
Pipe: M13A									
TOR	15.3	0.0	30.8	0.0	10.4	4.298	100	14.75	PF 3.8
BOR	1.5	0.0	40.6	0.0		0.066	TL	58.05	PE 6.0
Pipe: M14A									
BOR	1.5	0.0	40.6	0.0	10.4	4.298	120	1.00	PF 0.0
FLG	0.5	0.0	41.1	0.0		0.047	TL	1.00	PE 0.4
Pipe: M15A									
FLG	0.5	0.0	41.1	0.0	5.1	6.160	140	115.00	PF 1.0
BFP1	0.0	0.0	42.3	0.0		0.006	TL	159.00	PE 0.2
Pipe: M16A									
BFP2	0.0	0.0	46.3	0.0		FIXED PRESSURE LOSS DEVICE			
BFP1	0.0	0.0	42.3	0.0		4.0 psi, 472.1 gpm			
Pipe: M17A									
BFP2	0.0	0.0	46.3	0.0	5.1	6.160	140	35.00	PF 0.8
SOURCE	0.0	SRCE	47.1	(N/A)		0.006	TL	135.00	PE 0.0

DATE: 12/27/2024 \NAL VILLAGE\DESIGN\HYDRAULIC CALCS\R2 LAYOUT 12.02.24.SDF
 JOB TITLE: SYS 1

NOTES (HASS):

- (1) Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.003 gpm and a maximum imbalance at any node of 0.189 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 10.4 ft/sec at pipe M14.
- (4) Items listed in bold print on the cover sheet
 are automatically transferred from the calculation report.
- (5) Available pressure at source node SOURCE under full flow conditions is 49.27 psi with a flow of 736.37 gpm.

(6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D MATERIAL: DI HWC: 140

Diameter (in)	Equivalent Fitting Lengths in Feet					
	E	T	F	C	B	G
	Ell	Tee	45 ChkVlv	BfyVlv	GatVlv	
6.160	12.00	40.00	10.00	43.00	16.00	4.00

PAGE: Y MATERIAL: SCH7 HWC: 120


Diameter (in)	Equivalent Fitting Lengths in Feet								
	E	T	F	C	B	G	A	D	X
	Ell	Tee	45 ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	fleX	
4.298	9.30	31.90	4.70	24.70	7.80	3.00	28.90	28.90	0.00

PAGE: Z MATERIAL: SCH7 HWC: 100

Diameter (in)	Equivalent Fitting Lengths in Feet								
	E	T	F	C	B	G	A	D	X
	Ell	Tee	45 ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	fleX	
1.049	1.40	3.60	1.00	3.60	4.30	1.00	0.00	0.00	0.00
2.185	3.30	10.80	1.70	10.30	4.40	1.00	8.80	8.80	0.00
3.314	5.20	18.10	2.70	17.80	7.50	1.40	16.70	16.70	0.00
4.298	6.60	22.70	3.40	17.60	5.60	2.10	20.60	20.60	0.00

WATER SUPPLY ANALYSIS


Static: 59.00 psi Resid: 20.00 psi Flow: 1560.0 gpm



Note: (1) Dashed Lines indicate extrapolated values from Test Results

(2) On Site pressures are based on hose stream deduction at the source

WATER SUPPLY CURVE



DATE: 12/27/2024G:\South Puget Sound\Team1\Job Files\TI24051 to TI24075\TI24073 WA State Fairgrou
 JOB TITLE: SYS 1

Node Tag	Elevation (ft)	Static Pressure (psi)	Residual Pressure (psi)	Source Nodes	
				Flow (gpm)	Hose Stream Allowance (gpm)
SOURCE	0.00	59.0	20.0	1560	250

Node Data

Node Tag	Elevation (ft)	K	Req.Den. (gpm/ft^2)	Area (ft^2)
S1	9.50	5.60	0.150	100.0
S2	9.50	5.60	0.150	100.0
S3	9.50	5.60	0.150	80.0
S4	9.50	5.60	0.150	80.0
S5	9.50	5.60	0.150	50.0
S6	9.50	5.60	0.150	50.0
S7	9.50	5.60	0.150	80.0
S8	9.50	5.60	0.150	64.0
S9	9.50	5.60	0.150	72.0
S10	9.50	5.60	0.150	104.0
S11	9.50	5.60	0.150	104.0
S12	9.50	5.60	0.150	116.0
S13	12.80	5.60	0.100	116.0
S14	12.80	5.60	0.100	116.0
S15	12.80	5.60	0.100	116.0
S16	12.80	5.60	0.100	84.0
S17	12.80	5.60	0.100	84.0
S18	12.80	5.60	0.100	84.0
S19	18.50	5.60	0.100	116.0
S20	18.50	5.60	0.100	116.0
S21	18.40	5.60	0.100	116.0
S22	18.50	5.60	0.100	84.0
S23	18.50	5.60	0.100	84.0
S24	18.40	5.60	0.100	84.0
1	13.58	0.00	0.000	0.0
2	13.58	0.00	0.000	0.0
3	13.50	0.00	0.000	0.0
4	13.58	0.00	0.000	0.0
5	13.58	0.00	0.000	0.0
6	13.50	0.00	0.000	0.0
7	13.58	0.00	0.000	0.0
8	13.58	0.00	0.000	0.0
9	13.50	0.00	0.000	0.0
10	13.58	0.00	0.000	0.0
11	13.58	0.00	0.000	0.0
12	13.50	0.00	0.000	0.0
M1	12.00	0.00	0.000	0.0
M2	13.58	0.00	0.000	0.0
M3	12.00	0.00	0.000	0.0
M4	13.58	0.00	0.000	0.0
M5	12.00	0.00	0.000	0.0
M6	13.58	0.00	0.000	0.0
M7	12.00	0.00	0.000	0.0
M8	13.58	0.00	0.000	0.0
M9	12.00	0.00	0.000	0.0
M10	18.50	0.00	0.000	0.0
M11	16.42	0.00	0.000	0.0
M12	18.42	0.00	0.000	0.0
M13	11.50	0.00	0.000	0.0

DATE: 12/27/2024G:\South Puget Sound\Team1\Job Files\TI24051 to TI24075\TI24073 WA State Fairgrou

JOB TITLE: SYS 1

M14	13.42	0.00	0.000	0.0
M15	11.42	0.00	0.000	0.0
M16	13.42	0.00	0.000	0.0
M17	11.50	0.00	0.000	0.0
M18	16.50	0.00	0.000	0.0
M19	16.42	0.00	0.000	0.0
M20	18.42	0.00	0.000	0.0
M21	16.42	0.00	0.000	0.0
M22	18.42	0.00	0.000	0.0
M23	15.50	0.00	0.000	0.0
M24	16.33	0.00	0.000	0.0
TOR	15.25	0.00	0.000	0.0
BOR	1.50	0.00	0.000	0.0
FLG	0.50	0.00	0.000	0.0
BFP1	0.00	0.00	0.000	0.0
BFP2	0.00	0.00	0.000	0.0
SOURCE	0.0	SOURCE	0.000	0.0

Pipe Data

Pipe Tag	End Node	Tags	Length (ft)	Fittings (ft)	Diameter (in)	HWC
1	1	S1	27.00	4ET	1.049 (Z1.000)	100
2	2	S2	27.00	4ET	1.049 (Z1.000)	100
3	3	S3	27.00	4ET	1.049 (Z1.000)	100
4	4	S4	29.00	5ET	1.049 (Z1.000)	100
5	5	S5	27.00	4ET	1.049 (Z1.000)	100
6	6	S6	27.00	4ET	1.049 (Z1.000)	100
7	7	S7	31.00	5ET	1.049 (Z1.000)	100
8	8	S8	27.00	4ET	1.049 (Z1.000)	100
9	9	S9	27.00	4ET	1.049 (Z1.000)	100
10	10	S10	29.00	5ET	1.049 (Z1.000)	100
11	11	S11	27.00	4ET	1.049 (Z1.000)	100
12	12	S12	27.00	4ET	1.049 (Z1.000)	100
B1	1	2	10.00	0.0	2.185 (Z2.000)	100
B2	2	3	8.00	0.0	2.185 (Z2.000)	100
B3	3	M2	2.00	E	2.185 (Z2.000)	100
B4	4	5	8.00	0.0	2.185 (Z2.000)	100
B5	5	6	8.00	0.0	2.185 (Z2.000)	100
B6	6	M4	4.00	E	2.185 (Z2.000)	100
B7	7	8	8.00	0.0	2.185 (Z2.000)	100
B8	8	9	8.00	0.0	2.185 (Z2.000)	100
B9	9	M6	4.00	E	2.185 (Z2.000)	100
B10	10	11	8.00	0.0	2.185 (Z2.000)	100
B11	11	12	8.00	0.0	2.185 (Z2.000)	100
B12	12	M8	4.00	E	2.185 (Z2.000)	100
B13	S13	S14	10.50	0.0	2.185 (Z2.000)	100
B14	S14	S15	10.50	0.0	2.185 (Z2.000)	100
B15	S15	M14	3.58	E	2.185 (Z2.000)	100
B16	S16	S17	10.50	0.0	2.185 (Z2.000)	100
B17	S17	S18	10.50	0.0	2.185 (Z2.000)	100
B18	S18	M16	3.58	E	2.185 (Z2.000)	100
B19	S19	S20	10.50	0.0	2.185 (Z2.000)	100
B20	S20	S21	10.50	0.0	2.185 (Z2.000)	100
B21	S21	M20	3.58	E	2.185 (Z2.000)	100
B22	S22	S23	10.50	0.0	2.185 (Z2.000)	100
B23	S23	S24	10.50	0.0	2.185 (Z2.000)	100
B24	S24	M22	3.58	E	2.185 (Z2.000)	100
R1	M1	M2	1.58	T	2.185 (Z2.000)	100

DATE: 12/27/2024G:\South Puget Sound\Team1\Job Files\TI24051 to TI24075\TI24073 WA State Fairgrou

JOB TITLE: SYS 1

R2	M3	M4	1.58	T	2.185	(Z2.000)	100
R3	M5	M6	1.58	T	2.185	(Z2.000)	100
R4	M7	M8	1.58	T	2.185	(Z2.000)	100
R5	M9	M10	6.58	3ET	3.314	(Z3.000)	100
R6	M11	M12	2.00	ET	3.314	(Z3.000)	100
R7	M13	M14	1.92	T	2.185	(Z2.000)	100
R8	M15	M16	2.00	T	2.185	(Z2.000)	100
R9	M17	M18	5.00	2E	4.298	(Z4.000)	100
R10	M19	M20	2.00	T	2.185	(Z2.000)	100
R11	M21	M22	2.00	T	2.185	(Z2.000)	100
R12	M23	M24	0.83	2E	4.298	(Z4.000)	100
M1	M1	M3	8.00	0.0	3.314	(Z3.000)	100
M2	M3	M5	16.00	0.0	3.314	(Z3.000)	100
M3	M5	M7	8.00	0.0	3.314	(Z3.000)	100
M5	M7	M9	2.00	0.0	3.314	(Z3.000)	100
M8	M10	M12	28.83	0.0	3.314	(Z3.000)	100
M9	M13	M15	8.00	0.0	4.298	(Z4.000)	100
M10	M15	M17	5.33	0.0	4.298	(Z4.000)	100
M11	M18	M19	2.67	0.0	4.298	(Z4.000)	100
M12	M19	M21	8.00	0.0	4.298	(Z4.000)	100
M13	M21	M11	18.25	0.0	4.298	(Z4.000)	100
M14	M11	M24	49.83	E	4.298	(Z4.000)	100
M15	M23	TOR	93.83	2ET	4.298	(Z4.000)	100
M13A	TOR	BOR	14.75	TD	4.298	(Z4.000)	100
M14A	BOR	FLG	1.00	0.0	4.298	(4.000)	120
M15A	FLG	BFP1	115.00	2E2F	6.160	(D6.000)	140
M16A	BFP2	BFP1	Fixed Loss Device		-4.000		psi
M17A	BFP2	SOURCE	35.00	E2T2G	6.160	(D6.000)	140

DATE: 12/27/2024G:\South Puget Sound\Team1\Job Files\TI24051 to TI24075\TI24073 WA State Fairgrou
JOB TITLE: SYS 1