



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 08, 2025

**Inspection Result:** **FAILED**

**Permit Number:** B-20-0180

**Property Address:** 3601 9TH ST SW, PUYALLUP, WA 98373;

**Contractor:** THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

**To construct:** HOMEWOOD SUITES SOUTH HILL MALL MOTEL \*FEE DEFERRAL-SWR\* REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE \* REVISION (2) - 9/13/2024 - ADDITIONAL ROOM & MOVE BREAK ROOMSTOP WORK ORDER removed on 12/03/2024 by username 'Jeff Hill'.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1 room 132

1 ; fix electrical run outside of wall as discussed with contractor

2 ; provide engineer of record approval of A.T.S. system.

3 ; remove fire caulking from rod of A.T.S. system or provide approval from manufacturer of install of fire caulking at A.T.S. system.

4 ; insulate hot water supply lines.

room 139

1 ; complete nail plates at refrigeration line set lines.

2 ; provide engineer of record approval of A.T.S. system.

3 ; remove fire caulking from rod of A.T.S. system or provide approval from manufacturer of install of fire caulking at A.T.S. system.

4 ; complete firestop at top plates as discussed with contractor.

room 165

1 ; fix electrical run outside of wall as discussed with contractor



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

2 ; provide engineer of record approval of A.T.S. system.

3 ; remove fire caulking from rod of A.T.S. system or provide approval from manufacturer of install of fire caulking at A.T.S. system.

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684