



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 14, 2025

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** McKee is excavating the footings for building "D".

We flushed the fire line for building "G".

Flushed 2 - 2.5" hoses from the building flange and 2 - 2.5" hoses from the FDC. Both risers were flushed at the same time. The flush was performed 3 times at 15min. each time. "PASSED"

**Corrections:**

Sincerely,

Jason Little



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387