

Residential Sewer Service As-built

Service Address: 2902 Pioneer Way East **Building "B" South**

Subdivision: East Town Crossing Lot #: Bldgs B S

Permit No.: PRMU20240139 Contractor: Rick the Plumber & Co.

Pipe Type: ABS/PVC Pipe Size: 6"/4" No. of cleanouts: 2

Approved by: Jason Little, Eng Insp Date: 1/14/25

Inspector comments: _____

- point A is the 6" main sewer
 - point B is the first cleanout
 - point C is the second cleanout
 - point D is the 6"x4" eccentric reducer
 - There is a 7" piece of 6" PVC pipe between point C and D
 - point E is a 4" PVC x 4" ABS adapter coupling with a 4" piece of PVC pipe between points D and E
 - Between points E and F there is a 4" ABS st. 45 into the PVC x ABS adapter.
- the pipe then rises up from 7'10" to 3' from dirt grade.

