



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 16, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20240183

Property Address: 1023 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Construction of exterior infrastructure improvements including a new metal utility switchgear building, a new underground medium voltage electrical feeder to the data center building, installation of new diesel generators, along with exterior mechanical equipment and electrical equipment. - CENTERIS VOLTAGE PARK

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: site clean up and grading for the walkway.

Corrections:

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov
(253) 204-5633