



Branch #66955
600 Oakesdale Ave SW, Suite 100
Renton, WA 98057
844-538-3766
Web: everonsolutions.com

To:
City of Puyallup Fire Prevention
Permit #PRFA20241915

Ross #0593, 4102 S Meridian, Suite C, Puyallup, WA 98373

Correction have been completed as requested.

Reply to Submittal Rejection:

1. Update U.L. Certificate information.
2. All drop ceiling areas are cover on Page FA-2.
3. Change all Heat Detectors to Smoke Detector.
4. Add Smoke Detector to Men's R/R.
5. Add Smoke Detector to Women's R/R.
6. Add Smoke Detector to Janitor Closet.
7. Add Smoke Detector to Equipment Room.
8. Riser Diagram, Battery Calcs updated to accommodate added devices.

The modification design is by Milissa Johnson, NICET III,
Staff Designer II for Everon Solutions
Email: milissajohnson@everonsolutions.com

Fire Submittal
ADT Job # 300325818