



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 20, 2025

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** The contractor is working on the cap break of building H.  
JUT- sand bedding on the primary then backfilled with native. hoe pack and roller used for compaction

**Corrections:**

Sincerely,

Jeff Hill  
Development Engineering Inspector  
Jhill@PuyallupWA.gov  
(253) 204-5633