



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 23, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCNC20231287

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: LD Sanders Construction LLC 24920 SE 369th Place Enumclaw, WA 98022

To construct: Construction of a new Taco Time with drive-through on existing site.~
TACO TIME

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; Provide Geo Tech approval of 1.500 psf as required per structural sheet of Engineer of Record for building pad.
- 2 ; Provide special inspection approval of footing rebar, and hold downs are complete as per City approved plans.
- 3 ; Cover footings with blankets to protect from freezing weather as discussed with contractor.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684