



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 23, 2025

Inspection Result:

**PASSED W/
CONDITIONS**

Permit Number: PRMU20240139

Property Address: 2902 E PIONEER - BUILDING B, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - 2902 E PIONEER - ETC – APT BLDG B

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: protect slab with blankets if weather is below freezing temperature as discussed with contractor.

Corrections:

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684