



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 10, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20231620

Property Address: 110 9TH AVE SW, Unit: 10, PUYALLUP, WA 98371;

Contractor: ABSHER CONSTRUCTION PO BOX 280 PUYALLUP, WA 98371-0152

To construct: Construction of new main entry plaza including canopy, stormwater improvements, new water feature and pavers. Water, sewer and stormwater utilities will be extended for vendor hook-ups. Removal of existing fence, turnstyles, fountain and old building foundation. ~ FAIRGROUNDS GOLD GATE

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: NWC is excavating for the fountain footing

Corrections:

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov
(253) 204-5633