



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 27, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCNC20241019

**Property Address:** 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

**Contractor:** MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA 98409

**To construct:** Construct Early Learning Center

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide special inspection report at time of footing inspection .
- 2 ; provide geo- tech report for soil bearing requirements of 1,500 psf as required per engineers of record on city approved plans.
- 3 ; complete engineering requirements for relocation of storm and sewer from underneath building prior to footing inspection.
- 4 ; ground frozen at time of footing inspection, call for inspection after ground is thawed. cancel per contractor - not ready

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 840-6684