



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 27, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRMU20240401

**Property Address:** 801 SHAW RD BLDG D, PUYALLUP WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING D 3-story apartment building - EAST TOWN CROSSING - 2902  
E PIONEER -ETC – APT BLDG D

On this day we have inspected your construction for **Footings/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide special inspection report at time of footing inspection.
  - 2 ; ground frozen at time of footing inspection, call for inspection after ground is thawed.
  - 3 ; provide geo-tech approval letter for soil bearing requirement of 1,500 psf as required per E.O.R. as noted on city approved plans.
- not ready - cancel per contractor.

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)