

DRAWING SYMBOLS

ABBREVIATIONS


VICINITY MAP

PROJECT DIRECTORY

SHEET INDEX

Grid 1-12, Row H-G: Drawing symbols including North Indicator, Section Callout, Detail Callouts, Match Line, Key Note Callout, Existing/New Grids, Partition Type Callout, Elevation/Datum Callout, and Equipment Callout.

Grid 1-12, Row H-G: Abbreviations for electrical, mechanical, and structural components, including symbols for Amp, Fire Alarm, and various materials.



OWNER: BENAROYA CAPITAL, LLC
STRUCTURAL ENGINEER (SWITCHGEAR BUILDING): BRIENEN STRUCTURAL ENGINEERS
MECHANICAL ENGINEER: STANTEC
PROJECT DIRECTORY: PROJECT ADDRESS, PARCEL NUMBER, LEGAL DESCRIPTION, WORK UNDER THIS PERMIT, WORK UNDER SEPARATE PERMITS.

SHEET INDEX table listing sheet numbers (A-000-22 to A-501-22) and their corresponding titles (GENERAL INFORMATION, ENLARGED SITE PLAN, etc.).

PLAN SYMBOLS

Grid 1-12, Row F-E: Plan symbols for fire extinguishers, cabinets, signs, lighting fixtures, and various electrical and mechanical components.

Grid 1-12, Row F-E: Continuation of abbreviations for materials, finishes, and structural elements.

PROJECT INFORMATION

PROJECT ADDRESS: 1023 39TH AVENUE SE PUYALLUP, WA 98374-2121
PARCEL NUMBER: 0419034037
LEGAL DESCRIPTION: SECTION 03 TOWNSHIP 19 RANGE 04 QUARTER 43 PARCEL "1" OF ROS 2007-04-30-5001

SCOPE OF WORK

DATA CENTER BUILDING (PARCEL 0419034037)
EXTERIOR TOWER IMPROVEMENTS
WORK UNDER THIS PERMIT: CONSTRUCT NEW 625 SF LOW ENERGY METAL SWITCHGEAR SWITCHGEAR BUILDING.
WORK UNDER SEPARATE PERMITS: ELECTRICAL WORK.

CODE INFORMATION

APPLICABLE CODES: WASHINGTON BUILDING CODE, 2021 EDITION; WASHINGTON FIRE CODE, 2021 EDITION; WASHINGTON MECHANICAL CODE, 2021 EDITION; WASHINGTON PLUMBING CODE, 2021 EDITION; NATIONAL ELECTRIC CODE, 2023 EDITION; WASHINGTON STATE ENERGY CODE, 2021 EDITION.
LAND USE CODES: PUYALLUP MUNICIPAL CODE; EXISTING ZONING DESIGNATION: MP - BUSINESS PARK; PROPOSED ZONING DESIGNATION: MP - BUSINESS PARK.
BUILDING CODE INFORMATION: BUILDING OCCUPANCY GROUP: TYPE U, UTILITY; TYPE OF CONSTRUCTION: TYPE IIB, NON-SPRINKLERED; ALLOWABLE BUILDING HEIGHT (TABLE 504.3): 55'.

City of Puyallup Building Reviewed for Compliance stamp with date 12/24/2024 and time 11:47:52 AM. Includes City of Puyallup logo and project address: CENTERIS VOLTAGE PARK, 1023 39th Avenue South East, Puyallup, WA 98374-2121.

SECURITY SYMBOLS

Grid 1-12, Row B-A: Security symbols for cameras, card readers, door contacts, duress buttons, intercoms, motion detectors, and pin pads.

Grid 1-12, Row B-A: Continuation of abbreviations for materials, finishes, and structural elements.

GENERAL NOTES

- 1. DO NOT SCALE THE DRAWINGS.
2. THE DRAWINGS AND SPECIFICATIONS ARE COMPLEMENTARY. WHAT IS SHOWN ON ONE SHALL BE CONSTRUED TO BE REQUIRED BY BOTH.
3. THE CONTRACTOR SHALL VERIFY ALL FIELD CONDITIONS PRIOR TO COMMENCING ANY WORK. NOTIFY THE ARCHITECT IMMEDIATELY IF ANY CONDITIONS IMPACT THE IMPLEMENTATION OF THE DESIGN INTENT. ALL EXISTING ELEMENTS SHOWN ON THE DRAWINGS ARE INCLUDED WITHOUT ANY GUARANTEE OF ACCURACY.
4. ALL DIMENSIONS ARE SHOWN TO THE STRUCTURAL GRID OR FINISHED SURFACES, UNLESS NOTED OTHERWISE.
5. DETAILS ARE SHOWN ON THE DRAWINGS FOR THE FIRST OCCURRENCE OF THE CONDITION AND ARE TYPICAL FOR ALL OTHER SIMILAR CONDITIONS.
6. PROVIDE A MINIMUM OF 6" FROM AN ADJACENT FINISHED SURFACE TO THE EDGE OF ANY FINISHED OPENING.

CITY OF PUYALLUP Planning Division Approved Site Plan (253) 864-6165 MINIMUM SETBACK REQUIREMENTS. Includes setback requirements for Front, Rear, and Side yards. Staff: RNBrown, Date: 01/27/2025. Includes a note about liability for conflicts between approved building plans and approved civil construction plans.

OWNER: BENAROYA CAPITAL, LLC
Centeris Data Centers
9675 SE 36th St, Suite 1.15
Mercer Island, WA 98040
+1.253.200.4120

CONSULTANT: PRCTI20241387
City of Puyallup logo with Building, Engineering, Planning, Fire, Public Works, and Parks & Trails icons.

5538 REGISTERED ARCHITECT
LEONARD A. RUFF
STATE OF WASHINGTON

CASCADE MISSION CRITICAL, LLC
Data Center Consulting and Design
6210 36th Avenue N.E., Seattle, WA 98115
P: 206-294-1288 www.cascademissioncritical.com

CENTERIS VOLTAGE PARK
1023 39th Avenue South East
Puyallup, WA 98374-2121
WB-03 SOUTH UTILITY YARD
SWITCHGEAR BUILDING & GENERATORS

Table with columns ISSUED/REVISED and DATE. Row 1: PERMIT SUBMITTAL, 11/8/24. Row 2: PERMIT SUBMITTAL SET, NOVEMBER 8, 2024. Row 3: GENERAL NOTES.

**SITE INFORMATION**

PARCEL NO. 0419034037  
 ADDRESS: 1023 39TH AVENUE S.E.  
 PARCEL AREA: 15.77 ACRES

LEGAL DESCRIPTION  
 Section 03 Township 19 Range 04 Quarter 42 LOT 2 OF BLR 2022-03-22-5003 A POR OF BLR 2019-05-22-5002 LY IN CY OF PUYALLUP MORE PARTICULARLY DESC AS FOLL COM AT STONE MON MARKING S 1/4 COR OF SEC 3 SD STONE MON LIES N 86 DEG 31 MIN 42 SEC E 2621.06 FT FROM SE COR OF SD SEC 3 TH N 00 DEG 00 MIN 24 SEC E 2599.51 FT TH S 87 DEG 44 MIN 17 SEC E 496.53 FT TO POB TH S 00 DEG 04 MIN W 132.96 FT TH S 16 DEG 29 MIN 57 SEC E 15.96 FT TH S 00 DEG 00 MIN 36 SEC E 335.82 FT TH S 52 DEG 49 MIN 01 SEC E 132.81 FT TH S 89 DEG 15 MIN 41 SEC E 28.82 FT TH S 82 DEG 14 MIN 13 SEC E 58.63 FT TH S 53 DEG 48 MIN 38 SEC E 78.9 FT TH S 89 DEG 41 MIN 48 SEC E 655.79 FT TH S 83 DEG 08 MIN 38 SEC E 199.54 FT TH N 00 DEG 13 MIN 45 SEC E 602.4 FT TH N 87 DEG 44 MIN 17 SEC W 1118.01 FT TO POB EASE OF REC OUT OF 04-19-03-4-031 & 4-034 SEG 2019-0472 05/30/19 JP 20190652DC 03/31/22 JP


**OVERALL SCOPE OF WORK**

DATA CENTER BUILDING (PARCEL 0419034037)  
 EXTERIOR TENANT IMPROVEMENTS

**WORK UNDER THIS PERMIT**  
 CONSTRUCT NEW 625 SF LOW ENERGY METAL SWITCHGEAR SWITCHGEAR BUILDING.


INSTALL FIVE (5) 1250 KW STANDBY DIESEL GENERATORS EACH WITH 7,300 GALLON ABOVE GROUND UL-142 FUEL STORAGE TANKS.

**WORK UNDER SEPARATE PERMITS**  
 ELECTRICAL WORK



**OWNER:**  
 BENAROYA CAPITAL, LLC  
 Centeris Data Centers  
 9675 SE 36th St, Suite 115  
 Mercer Island, WA 98040  
 +1.253.200.4120

**CONSULTANT:**  
**PRCTI20241387**  
 City of Puyallup  
 Development, Planning Services  
 Building Planning  
 Engineering Public Works  
 Fire Traffic



**CASCADE MISSION CRITICAL, LLC**  
 Data Center Consulting and Design  
 6210 36th Avenue N.E., Seattle, WA 98115  
 P: 206-294-1288 www.cascadecritical.com

**CENTERIS VOLTAGE PARK**  
 1023 39th Avenue South East  
 Puyallup, WA 98374-2121  
 WB-03 SOUTH UTILITY YARD  
 SWITCHGEAR BUILDING & GENERATORS


ISSUED/REVISED	DATE
PERMIT SUBMITTAL	11/8/24

PERMIT SUBMITTAL SET  
 NOVEMBER 8, 2024  
 OVERALL SITE PLAN

**A-101-22**

H  
G  
F  
E  
D  
C  
B  
A

1 2 3 4 5 6 7 8 9 10 11 12




- LEGEND**
- ACC AIR COOLED CHILLER PER MECH. UNDER SEPARATE PERMIT
  - FCU FLUID COOLER PER MECH. UNDER SEPARATE PERMIT
  - MVSX MEDIUM VOLTAGE SWITCH PER ELEC. UNDER SEPARATE PERMIT
  - TRF TRANSFORMER PER ELEC. UNDER SEPARATE PERMIT
  - LB LOAD BANK PER ELEC. UNDER SEPARATE PERMIT

**(A1) ENLARGED SITE PLAN - SOUTH UTILITY YARD**  
SCALE: 1/8" = 1'-0"

Incomplete site plan. Please refer to the CoP Site Plan Standards (available to download in the permitting portal). Revise the site plan to include items 1-3 and items A-X of the City's Site Plan Standards. In particular, overlay the civil utility plan on the architectural drawings to verify there are no significant conflicts. Since the building permit cannot be issued until civil construction permit is issued first and the building plans must match the approved civil plans, please coordinate your final building permit submittal with the approval of the civil permit to avoid redundant or surplus building permit submittals and fees. [CONSTRUCTION PLAN SET - South SG Bldg & Generator-Arch, sheet A-102-22]

**OWNER:**  
BENAROYA CAPITAL, LLC  
Centeris Data Centers  
9675 SE 36th St, Suite 115  
Mercer Island, WA 98040  
+1.253.200.4120

**CONSULTANT:**  
PRCTI20241387  
City of Puyallup  
Development, Planning Services  
Building Planning  
Engineering Public Works  
Fire Traffic



**CASCADE MISSION CRITICAL, LLC**  
Data Center Consulting and Design  
6210 36th Avenue N.E., Seattle, WA 98115  
P: 206-294-1288 www.cascadecommissioncritical.com

**CENTERIS VOLTAGE PARK**  
1023 39th Avenue South East  
Puyallup, WA 98374-2121  
WB-03 SOUTH UTILITY YARD  
SWITCHGEAR BUILDING & GENERATORS

ISSUED/REVISED DATE  
PERMIT SUBMITTAL 11/8/24

PERMIT SUBMITTAL SET  
NOVEMBER 8, 2024


ENLARGED SITE PLAN  
SOUTH UTILITY YARD - WEST  
OVERALL LAYOUT

**A-102-22**


H  
G  
F  
E  
D  
C  
B  
A

**LIGHTING FIXTURE LEGEND**


- F1: EXTERIOR WALL MOUNTED PER ELEC.
- F2: INTERIOR PENDANT MOUNTED PER ELEC.
- F3: WALL MOUNTED EXIT SIGN ABOVE DOOR PER ELEC.



**E2 SWITCHGEAR BUILDING-FLOOR PLAN**  
SCALE: 1/4" = 1'-0"



**E8 SWITCHGEAR BUILDING-REFLECTED CEILING PLAN**  
SCALE: 1/4" = 1'-0"



**B1 1-HOUR RATED EXTERIOR WALL ASSEMBLY**  
SCALE: NO SCALE

**EXTERIOR WALL TYPES**


- RATED ASSEMBLIES**
- A1** 1 HOUR FIRE RESISTIVE EXTERIOR BEARING WALL  
EXTERIOR SIDE: FIBER CEMENT SIDING, AIR/WATER BARRIER, 1 LAYER 5/8" DENSGLOSS FIREGUARD X SHEATHING, EXTERIOR CLADDING TO BE ATTACHED THROUGH GLASS MAT PANEL TO STUDS.  
INTERIOR SIDE: 1 LAYER 5/8" FIREGUARD X GYPSUM PANELS  
CONSTRUCT IN ACCORDANCE WITH UL U425  
REFER TO DETAIL B1/A103-22 FOR DETAILED ASSEMBLY INFORMATION.
  - B1** 1 HOUR FIRE RESISTIVE EXTERIOR BEARING WALL  
EXTERIOR SIDE: 1 LAYER 5/8" DENSGLOSS FIREGUARD X SHEATHING.  
INTERIOR SIDE: 1 LAYER 5/8" FIREGUARD X GYPSUM PANELS  
CONSTRUCT IN ACCORDANCE WITH UL U425  
REFER TO DETAIL B1/A103-22 FOR DETAILED ASSEMBLY INFORMATION.
- NON-RATED ASSEMBLIES**
- B0** NON-RATED EXTERIOR NON-BEARING WALL  
EXTERIOR SIDE: PRE-FINISHED METAL SIDING, AIR/WATER BARRIER, 5/8" DENSGLOSS GYPSUM SHEATHING, 6" METAL STUDS.
  - C0** NON-RATED EXTERIOR NON-BEARING WALL  
EXTERIOR SIDE: 7/16" CEMENT FIBER SIDING PANELS, AIR/WATER BARRIER, 7/16" OSB SHEATHING, 6" METAL STUDS.
  - D0** NON-RATED EXTERIOR NON-BEARING WALL  
EXTERIOR SIDE: CEMENT FIBER PANELS, AIR/WATER BARRIER, 7/16" OSB SHEATHING, 6" METAL STUDS.
  - E0** NON-RATED EXTERIOR NON-BEARING WALL  
EXTERIOR SIDE: CEMENT FIBER PANELS, AIR/WATER BARRIER, 7/16" OSB SHEATHING, 6" METAL STUDS.  
INTERIOR SIDE: 7/16" OSB SHEATHING

**ROOF DRAINAGE CALCULATION - 2021 WPC**

ROOF AREA: 738.75 SF  
 RAINFALL FACTOR (R) = 1.4  
 GPM = R X A X 0.0104  
 GPM = 1.4 X 738.75 X 0.0104  
 TOTAL GPM = 10.76  
 2" DIA. DOWNSPOUT = 30 GPM  
 MIN. NUMBER OF DOWNSPOUTS: 1  
 NUMBER OF 2" DIA. DOWNSPOUTS PROVIDED: 3

**ENERGY CODE COMPLIANCE - 2021 WSEC**


BUILDING DESIGNED AS A LOW ENERGY BUILDING PER C402.1.1.1 WITH NO HEATING  
 BUILDING ENVELOPE - EXEMPT FROM THERMAL ENVELOPE REQUIREMENTS



**A8 SWITCHGEAR BUILDING-ROOF PLAN**  
SCALE: 1/4" = 1'-0"

**OWNER:**  
 BENAROYA CAPITAL, LLC  
 Centeris Data Centers  
 9675 SE 36th St, Suite 115  
 Mercer Island, WA 98040  
 +1.253.200.4120

**CONSULTANT:**  
 PRCTI20241387  
 City of Paywall  
 Development Services  
 Building  
 Engineering  
 Planning  
 Fire  
 Public Works  
 Traffic




**CASCADE MISSION CRITICAL, LLC**  
 Data Center Consulting and Design  
 6210 36th Avenue N.E., Seattle, WA 98115  
 P: 206-294-1288 www.cascadecritical.com

**CENTERIS VOLTAGE PARK**  
 1023 39th Avenue South East  
 Paywall, WA 98374-2121  
 WB-03 SOUTH UTILITY YARD  
 SWITCHGEAR BUILDING & GENERATORS


ISSUED/REVISED	DATE
PERMIT SUBMITTAL	11/8/24

PERMIT SUBMITTAL SET  
 NOVEMBER 8, 2024  
 SWITCHGEAR BUILDING  
 FLOOR PLAN  
 REFLECTED CEILING PLAN  
 ROOF PLAN

**A-103-22**




**F1 SOUTH ELEVATION**  
NO SCALE




**F8 EAST ELEVATION**  
NO SCALE

NOTE: REFER TO ELECTRICAL DRAWINGS FOR LIGHTING FIXTURE TYPES.




**C1 NORTH ELEVATION**  
NO SCALE



**C8 WEST ELEVATION**  
NO SCALE

OWNER:  
BENAROYA CAPITAL, LLC  
Centeris Data Centers  
9675 SE 36th St, Suite 115  
Mercer Island, WA 98040  
+1.253.200.4120

CONSULTANT:  
**PRCTI20241387**  
City of Paywall  
Development & Permitting Services  
Building Planning  
Engineering Public Works  
Fire Trails



CASCADE MISSION CRITICAL, LLC  
Data Center Consulting and Design  
6210 36th Avenue N.E., Seattle, WA 98115  
P: 206-294-1288 www.cascadecommissioncritical.com


CENTERIS VOLTAGE PARK  
1023 39th Avenue South East  
Payallup, WA 98374-2121  
WB-03 SOUTH UTILITY YARD  
SWITCHGEAR BUILDING & GENERATORS

ISSUED/REVISED	DATE
PERMIT SUBMITTAL	11/8/24

PERMIT SUBMITTAL SET  
NOVEMBER 8, 2024  
SOUTH UTILITY YARD  
SWITCHGEAR BUILDING  
EXTERIOR ELEVATIONS

**A-301-22**

H  
G  
F  
E  
D  
C  
B  
A



**E5 METAL SIDING MS1 PRODUCT DATA**  
SCALE: NO SCALE

**Product Description**  
TwinLok™ metal roof panels offer an economical option for building owners. This mechanically double-locked standing seam roof system is available with a 1-1/2\"/>

**Design Characteristics**

- Available with 1 1/2-inch or 2-inch seam
- Mechanically double-locked interlocking seam
- Designed for use on slopes of 2:12 and above (with a solid deck and underlayment)
- Heavy concealed clips allow thermal movement
- Factory-applied hot-melt seam sealant
- Center of panels can be striated or flat
- Available widths for TwinLok 1.5: 12, 16 and 18-inch
- Available widths for TwinLok 2.0: 12, 16 and 18-inch

**Available Materials**

- Steel: 24 and 22-gauge
- Aluminum: .032\"/>
- Zinc: 0.8mm and 1.0mm

**Product Testing**



- UL 580 Class 90 windstorm rating
- ASTM E-283 air infiltration
- ASTM E-330
- ASTM E-331 water penetration
- ASTM E 1592 uniform static air pressure

**Warranties**

- 20-year finish warranty for Kynar® coating
- Materials and workmanship warranty
- Weather-tight warranty on qualifying applications



**A5 METAL ROOFING PRODUCT DATA**  
SCALE: NO SCALE



**PRODUCTS AND MATERIALS**

- STANDING SEAM METAL ROOFING: IMETCO TWIN LOK, 1.5\"/>
- COLOR: PREWEATHERED GALVALUME
- METAL SIDING (MS1): IMETCO LATTITUDE LW12S-12F, HORIZONTAL APPLICATION, COLOR: PREWEATHERED GALVALUME
- EXTERIOR SIDING PANELS: HARDIE PANEL - 5/16\"/>
- AIR/WATER BARRIER: HARDIEWRAP WEATHER BARRIER W/HARDIEWRAP PRO-FLASHING, FLEX FLASHING AND SEAM TAPE.
- VERTICAL METAL REVEAL: TAMLYN BRV12516, PRIMED FINISH
- HORIZONTAL Z: TAMLYN XZH516 PRIMED FINISH
- WINDOW/HEAD FLASHING: TAMLYN XWF788, PRIMED FINISH
- STARTER STRIP: TAMLYN XS516, PRIMED FINISH
- OUTSIDE CORNER: TAMLYN XOCLP516, PRIMED FINISH
- J-MOLD: TAMLYN JMH51610, PRIMED FINISH

**OWNER:**  
BENAROYA CAPITAL, LLC  
Centeris Data Centers  
9675 SE 36th St, Suite 115  
Mercer Island, WA 98040  
+1.253.200.4120

**CONSULTANT:**  
PRCTI20241387  
City of Pasayten  
Development & Planning Services  
Building Planning  
Engineering Public Works  
Fire Trails

5538 REGISTERED ARCHITECT  
LEONARD A. RUFF  
STATE OF WASHINGTON


**CASCADE MISSION CRITICAL, LLC**  
Data Center Consulting and Design  
6210 36th Avenue N.E. Seattle, WA 98115  
P: 206-294-1288 www.cascademissioncritical.com

**CENTERIS VOLTAGE PARK**  
1023 39th Avenue South East  
Puyallup, WA 98374-2121  
WB-03 SOUTH UTILITY YARD  
SWITCHGEAR BUILDING & GENERATORS


ISSUED/REVISED DATE  
PERMIT SUBMITTAL 11/8/24

PERMIT SUBMITTAL SET  
NOVEMBER 8, 2024  
SWITCHGEAR BUILDING  
BUILDING SECTIONS


**A-302-22**




**G1 METAL ROOF RIDGE**  
SCALE: 1 1/2" = 1'-0"




**G3 METAL ROOF RAKE EAVE**  
SCALE: 1 1/2" = 1'-0"




**G5 METAL ROOF EAVE @ GUTTER**  
SCALE: 1 1/2" = 1'-0"




**G7 WALL AT FOUNDATION**  
SCALE: 1 1/2" = 1'-0"




**G9 WALL AT FOUNDATION**  
SCALE: 1 1/2" = 1'-0"




**G11 DOOR HEAD (LOUVER HEAD SIM.)**  
SCALE: 1 1/2" = 1'-0"




**E1 CONDUIT PENETRATION @ EXTERIOR WALL**  
SCALE: 1 1/2" = 1'-0"




**E5 SIDING REVEALS - ELEVATION**  
SCALE: 3" = 1'-0"



**E7 OUTSIDE CORNER**  
SCALE: 1 1/2" = 1'-0"



**E9 INSIDE CORNER @ RATED WALL**  
SCALE: 1 1/2" = 1'-0"



**E11 DOOR JAMB (LOUVER JAMB SIM.)**  
SCALE: 1 1/2" = 1'-0"


NO.	TYPE	CONFIG.	WIDTH	HEIGHT	MAT.	F.R.	FRAME MAT.	FRAME F.R.	HW.	SILL	JAMB	HEAD	COMMENTS
250A	A	3GL	3'-0"	8'-0"	HM	NR	HM-PTD.	NR	1	---	E11/A501-22	G11/A501-22	
250B	B	DBL	6'-0"	8'-0"	HM	NR	HM-PTD.	NR	2	---	E11/A501-23	G11/S201-22	

**DOOR HARDWARE SCHEDULE**

- HW-1 SINGLE, NON-RATED**  
 3 EA. BUTT HINGES  
 1 EA. ELEC. TRANSFER HINGE  
 1 EA. ELEC. RIM EXIT DEVICE WITH LEVER HANDLE EXTERIOR TRIM  
 1 EA. STRIKE  
 1 EA. CLOSER  
 1 EA. WEATHERSTRIP  
 1 EA. DRIP EDGE  
 1 EA. BOTTOM DOOR SWEEP  
 1 EA. SADDLE THRESHOLD  
 2 EA. CARD READER (BY OWNER)

- HW-2 PAIR, NON-RATED**  
 6 EA. BUTT HINGES  
 2 EA. ELEC. TRANSFER HINGE  
 2 EA. SURFACE MTD. ELEC. EXIT DEVICE WITH SURFACE MTD. RODS AND LEVER HANDLE EXTERIOR TRIM  
 2 EA. FLOOR AND HEAD STRIKES  
 2 EA. CLOSER  
 1 EA. WEATHERSTRIP  
 2 EA. SPLIT ASTRAGAL RUBBER SEALS  
 1 EA. DRIP EDGE  
 2 EA. BOTTOM DOOR SWEEP  
 1 EA. SADDLE THRESHOLD  
 2 EA. CARD READER (BY OWNER)

**DOOR TYPES**



OWNER:  
**BENAROYA CAPITAL, LLC**  
 Centeris Data Centers  
 9675 SE 36th St, Suite 115  
 Mercer Island, WA 98040  
 +1.253.200.4120

CONSULTANT:  
**PRCTI20241387**  
 City of Paywall  
 Development & Permitting Services  
 Building Planning  
 Engineering Public Works  
 Fire Trails

5538 REGISTERED ARCHITECT  
**LEONARD A. RUFF**  
 STATE OF WASHINGTON

**CASCADE MISSION CRITICAL, LLC**  
 Data Center Consulting and Design  
 6210 36th Avenue N.E., Seattle, WA 98115  
 P: 206-294-1288 www.cascadecritical.com

**CENTERIS VOLTAGE PARK**  
 1023 39th Avenue South East  
 Puyallup, WA 98374-2121  
 WB-03 SOUTH UTILITY YARD  
 SWITCHGEAR BUILDING & GENERATORS

ISSUED/REVISED	DATE
PERMIT SUBMITTAL	11/8/24

PERMIT SUBMITTAL SET  
 NOVEMBER 8, 2024  
 DETAILS  
 SCHEDULES

**A-501-22**