





December 27, 2024

PRCTI20242004




**STRUCTURAL CALCULATIONS**  
(Permit Submittal)

**CENTERIS DATA CENTER  
LEVEL 2 DATA CENTER TI**  
1023 39<sup>th</sup> Avenue SE  
Puyallup, WA 98374

Calculations required to be provided by the Permittee on site for all inspections

Quantum Job Number: 23444.01

*Prepared for:*  
CENTERIS DATA CENTERS  
18300 Cascade Avenue S  
Seattle, WA 981188



*Prepared by:*  
QUANTUM CONSULTING ENGINEERS  
1511 Third Avenue, Suite 323  
Seattle, WA 98101  
TEL 206.957.3900  
FAX 206.957.3901

# Structural Design Criteria

---

**Building Code:** 2021 International Building Code  
**Building Department:** City of Puyallup

## Seismic Criteria

$S_s$ : 1.26  
 $S_1$ : 0.43      Seismic Soil Site Class: D  
 $S_{ds}$ : 1.01      Seismic Design Category: D  
 $S_{d1}$ : 0.50

## Materials Criteria

### Concrete (28 Day Strength):

Foundation/Slab on Grade       $F'_c$ = 3,000 PSI  
Walls and Columns       $F'_c$ = 3,000 PSI

### Reinforcing Steel:

Grade 60       $F_y$ = 60,000 PSI

### Structural Steel:

Wide-Flange Sections: A-992       $F_y$ = 50,000 PSI  
Miscellaneous Sections: A-36       $F_y$ = 36,000 PSI  
Tube Sections: A-500       $F_y$ = 46,000 PSI  
Pipe Sections: A-53       $F_y$ = 35,000 PSI  
Welding       $F_y$ = 70,000 PSI

⚠ This is a beta release of the new ATC Hazards by Location website. Please [contact us](#) with feedback.

ℹ The ATC Hazards by Location website will not be updated to support ASCE 7-22. [Find out why.](#)

# ATC Hazards by Location

## Search Information

**Address:** 1015 39th Ave SE Puyallup, WA 98374  
**Coordinates:** 47.1590004, -122.2794422  
**Elevation:** 489 ft  
**Timestamp:** 2023-12-01T15:14:56.409Z  
**Hazard Type:** Seismic  
**Reference Document:** ASCE7-16  
**Risk Category:** III  
**Site Class:** D-default



## Basic Parameters

Name	Value	Description
S <sub>S</sub>	1.257	MCE <sub>R</sub> ground motion (period=0.2s)
S <sub>1</sub>	0.433	MCE <sub>R</sub> ground motion (period=1.0s)
S <sub>MS</sub>	1.508	Site-modified spectral acceleration value
S <sub>M1</sub>	* null	Site-modified spectral acceleration value
S <sub>DS</sub>	1.005	Numeric seismic design value at 0.2s SA
S <sub>D1</sub>	* null	Numeric seismic design value at 1.0s SA

\* See Section 11.4.8

## Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F <sub>a</sub>	1.2	Site amplification factor at 0.2s
F <sub>v</sub>	* null	Site amplification factor at 1.0s
CR <sub>S</sub>	0.914	Coefficient of risk (0.2s)
CR <sub>1</sub>	0.898	Coefficient of risk (1.0s)
PGA	0.5	MCE <sub>G</sub> peak ground acceleration
F <sub>PGA</sub>	1.2	Site amplification factor at PGA
PGA <sub>M</sub>	0.6	Site modified peak ground acceleration
T <sub>L</sub>	6	Long-period transition period (s)
SsRT	1.257	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.375	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	1.5	Factored deterministic acceleration value (0.2s)
S1RT	0.433	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.483	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGA <sub>d</sub>	0.5	Factored deterministic acceleration value (PGA)

\* See Section 11.4.8

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

## COOLING PIPES SUSPENDED FROM LEVEL 3

### • PIPE LOADS

NORTH PIPES: 10"  $\emptyset$  43 PLF EACH (FULL)

SOUTH PIPES: 8"  $\emptyset$  30 PLF EACH (FULL)

ADD 20 PLF MISC LOAD FOR FITTINGS ETC

CONTROLLING LINE LOAD IS  $W = (2) 43 \text{ PLF} + 20 \text{ PLF}$

$$W = 106 \text{ PLF}$$

ROUND LOAD UP TO 120 PLF

SUPPORTS ARE SPACED @ 8' o.c.

$$P = 120 \text{ PLF} (8')$$

$$P = 960 \text{ lb @ EA. SUPPORT}$$

### • UNISTRUT GRAVITY DESIGN

$$\text{SPAN} = 3'-0"$$

USE P1000  $(15\frac{1}{8} \times 15\frac{1}{8} \times 12 \text{ GA. STACKED})$

$$\text{ALL. LOAD} = 1130 \text{ lb}$$

$$V_c = 0.85 \leq 1.0 \text{ OK FOR GRAVITY}$$

### • LATERAL DESIGN

$$S_{DS} = 1.01 \quad \alpha_p = 2.5 \quad R_p = 6.0 \quad I_p = 1.5 \quad 2/h = 0.50$$

$$F_p = \frac{0.4(2.5)(1.01)(960 \text{ lb})}{(6/1.5)} (1 + 2(0.5)) \quad (\text{ASCE 7-16 EQ 13.3-1})$$

$$F_p = 485 \text{ lb CONTROLS}$$

$$F_{p \text{ MIN}} = 0.3(1.01)(960 \text{ lb})$$

$$F_{p \text{ MIN}} = 291 \text{ lb}$$



**QUANTUM** | CONSULTING ENGINEERS

1511 THIRD AVENUE  
SUITE 323  
SEATTLE, WA 98101  
TEL 206.957.3900  
FAX 206.957.3901  
www.quantumce.com

CENTERIS

project

CENTERIS

client

12/26/24 23444.01

date

Tvm

designer

checked by


project no.

sheet

• TRAPEZE SUPPORT  
 ALL BRACES ARE TENSION ONLY

$P = 960 \text{ lb } / 2$   
 $P = 480 \text{ lb}$   
 $F_p = 485 \text{ lb} = EQ$

SEE RISA 2D MODEL



**QUANTUM** | CONSULTING ENGINEERS

1511 THIRD AVENUE  
 SUITE 323  
 SEATTLE, WA 98101  
 TEL 206.957.3900  
 FAX 206.957.3901  
 www.quantumce.com

CENTERIS

project

CENTERIS

client

12/26/24 23444.01

date



project no.



TJM

designer

sheet

checked by







Member Length (ft) Displayed

Quantum Consulting Engin...

Travis Michaud P.E. S.E.

Dec 27, 2024 at 4:53 AM

Chiller Pipe Unistrut.r2d



Member Length (ft) Displayed  
Loads: BLC 1, Dead



Quantum Consulting Engin...

Travis Michaud P.E. S.E.

Dec 27, 2024 at 4:53 AM

Chiller Pipe Unistrut.r2d





Loads: BLC 2, Seismic  
Envelope Only Solution



Quantum Consulting Engin...

Travis Michaud P.E. S.E.

Dec 27, 2024 at 9:12 AM

Chiller Pipe Unistrut.r2d







MAX CABLE TENSION IS 700 LB. 1/4" CABLE IS OK.  
MAX ROD TENSION IS 700 LB. 1/2" ROD IS OK.  
MAX ROD COMPRESSION IS 50 LBS,  
 $KL/r = 672$   
 $F_e = 0.63 \text{ KSI}$   
 $P_u/\Omega = 74 \text{ LB} > 50 \text{ LB}$  EULER BUCKLING OK.  
Envelope Only Solution  
Member Axial Forces (k) (Enveloped)

Quantum Consulting Engin...

Travis Michaud P.E. S.E.

Dec 27, 2024 at 9:14 AM

Chiller Pipe Unistrut.r2d



**ENVELOPED REACTIONS IN OMEGA COMBINATION**

Envelope Only Solution

Y-direction Reaction Units are k and k-ft (Enveloped)

Quantum Consulting Engin...

Travis Michaud P.E. S.E.

Dec 27, 2024 at 9:18 AM

Chiller Pipe Unistrut.r2d

**www.hilti.com**

Company: Quantum Consulting Engineers  
Address: 1511 Third Ave, Suite 323  
Phone | Fax: 2069573900 |  
Design: Metal deck - Dec 27, 2024  
Fastening point:

Page: 1  
Specifier: Travis Michaud  
E-Mail: tmichaud@quantumce.com  
Date: 12/27/2024

**Specifier's comments:****1 Input data**

Metal deck: Verco W3 Formlok 3"  
Metal deck type: W1  
Anchor installation: In the lower flute of concrete-filled metal deck  
**Anchor type and diameter:** **KWIK HUS-EZ (KH-EZ) (Carbon Steel) 1/2 (4 1/4)**  
Item number: 418075 KH-EZ 1/2"x4 1/2"  
Specification text: Hilti  $\varnothing$  1/2 in KWIK HUS-EZ (KH-EZ) (Carbon Steel) with 4.25 in nominal embedment depth per ICC-ES ESR-3027 , SAFEset - automatic cleaning installation per MPII  
Effective embedment depth:  $h_{ef,act} = 3.220$  in.,  $h_{nom} = 4.250$  in.  
Material: Carbon Steel  
Evaluation Service Report: ESR-3027  
Issued | Valid: 12/1/2023 | 12/1/2025  
Proof: Design Method ACI 318-19 / Mech in concrete over metal deck installation  
Stand-off installation:  
Profile:  
Base material: cracked concrete, 3000,  $f'_c = 3,000$  psi;  $h = 3.500$  in.  
**Installation:** **automatic cleaned drilled hole, Installation condition: Dry**  
Seismic loads (cat. C, D, E, or F) Tension load: yes (17.10.5.3 (d))  
Shear load: yes (17.10.6.3 (c))






# Hilti PROFIS Engineering 3.1.9

www.hilti.com

Company: Quantum Consulting Engineers  
Address: 1511 Third Ave, Suite 323  
Phone | Fax: 2069573900 |  
Design: Metal deck - Dec 27, 2024  
Fastening point:

Page: 2  
Specifier: Travis Michaud  
E-Mail: tmichaud@quantumce.com  
Date: 12/27/2024

## Geometry [in.] & Loading [lb, in.lb]





# Hilti PROFIS Engineering 3.1.9

www.hilti.com

Company:	Quantum Consulting Engineers	Page:	3
Address:	1511 Third Ave, Suite 323	Specifier:	Travis Michaud
Phone   Fax:	2069573900	E-Mail:	tmichaud@quantumce.com
Design:	Metal deck - Dec 27, 2024	Date:	12/27/2024
Fastening point:			

## 1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1,100; V <sub>x</sub> = 0; V <sub>y</sub> = 800; M <sub>x</sub> = 0; M <sub>y</sub> = 0; M <sub>z</sub> = 0;	yes	97

## 2 Load case/Resulting anchor forces

### Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	1,100	800	0	800

## 3 Tension load

	Load N <sub>ua</sub> [lb]	Capacity $\phi$ N <sub>n</sub> [lb]	Utilization $\beta_N = N_{ua}/\phi N_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Pullout Strength*	1,100	1,645	67	OK
Concrete Breakout Failure**	N/A	N/A	N/A	N/A

\* highest loaded anchor    \*\*anchor group (anchors in tension)

### 3.1 Pullout Strength

N <sub>p,Deck</sub> [lb]	(f' <sub>c</sub> /3000) <sup>α</sup>	α	λ <sub>a</sub>	φ	φ <sub>seismic</sub>	φ <sub>nonductile</sub>	φ N <sub>pn,Deck,f<sub>c</sub></sub> [lb]
3,375	1.000	0.500	1.000	0.650	0.750	1.000	1,645



# Hilti PROFIS Engineering 3.1.9

www.hilti.com

Company:	Quantum Consulting Engineers	Page:	4
Address:	1511 Third Ave, Suite 323	Specifier:	Travis Michaud
Phone   Fax:	2069573900	E-Mail:	tmichaud@quantumce.com
Design:	Metal deck - Dec 27, 2024	Date:	12/27/2024
Fastening point:			

## 4 Shear load

	Load $V_{ua}$ [lb]	Capacity $\phi V_n$ [lb]	Utilization $\beta_V = V_{ua} / \phi V_n$	Status
Steel Strength*	800	1,293	62	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength*	N/A	N/A	N/A	N/A
Concrete edge failure in direction **	N/A	N/A	N/A	N/A

\* highest loaded anchor    \*\*anchor group (relevant anchors)  
 When the input edge distance is set to "infinity", edge breakout verification is not performed in that direction

### 4.1 Steel Strength

$V_{sa,Deck}$ [lb]	$\alpha_{V,seis}$	$\phi$	$\phi V_{sa,Deck}$ [lb]	$V_{ua}$ [lb]
2,155	0.600	0.600	1,293	800

## 5 Combined tension and shear loads, per ACI 318-19 section 17.8

$\beta_N$	$\beta_V$	$\zeta$	Utilization $\beta_{NV}$ [%]	Status
0.669	0.619	5/3	97	OK

$$\beta_{NV} = \beta_N^\zeta + \beta_V^\zeta \leq 1$$





## Hilti PROFIS Engineering 3.1.9

www.hilti.com

Company:	Quantum Consulting Engineers	Page:	5
Address:	1511 Third Ave, Suite 323	Specifier:	Travis Michaud
Phone   Fax:	2069573900	E-Mail:	tmichaud@quantumce.com
Design:	Metal deck - Dec 27, 2024	Date:	12/27/2024
Fastening point:			

### 6 Warnings

- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (AS 5216:2021, ETAG 001/Annex C, EOTA TR029 etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with CBFEM to limit the stress of the anchor plate based on the assumptions explained above. The proof if the rigid anchor plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!
- The equations presented in this report are based on imperial units. When inputs are displayed in metric units, the user should be aware that the equations remain in their imperial format.
- Condition A applies where the potential concrete failure surfaces are crossed by supplementary reinforcement proportioned to tie the potential concrete failure prism into the structural member. Condition B applies where such supplementary reinforcement is not provided, or where pullout or pryout strength governs.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- For additional information about ACI 318 strength design provisions, please go to <https://submittals.us.hilti.com/PROFISAnchorDesignGuide/>
- "An anchor design approach for structures assigned to Seismic Design Category C, D, E or F is given in ACI 318-19, Chapter 17, Section 17.10.5.3 (a) that requires the governing design strength of an anchor or group of anchors be limited by ductile steel failure. If this is NOT the case, the connection design (tension) shall satisfy the provisions of Section 17.10.5.3 (b), Section 17.10.5.3 (c), or Section 17.10.5.3 (d). The connection design (shear) shall satisfy the provisions of Section 17.10.6.3 (a), Section 17.10.6.3 (b), or Section 17.10.6.3 (c)."
- Section 17.10.5.3 (b) / Section 17.10.6.3 (a) require the attachment the anchors are connecting to the structure be designed to undergo ductile yielding at a load level corresponding to anchor forces no greater than the controlling design strength. Section 17.10.5.3 (c) / Section 17.10.6.3 (b) waive the ductility requirements and require the anchors to be designed for the maximum tension / shear that can be transmitted to the anchors by a non-yielding attachment. Section 17.10.5.3 (d) / Section 17.10.6.3 (c) waive the ductility requirements and require the design strength of the anchors to equal or exceed the maximum tension / shear obtained from design load combinations that include E, with E increased by  $\omega_0$ .
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII). Reference ACI 318-19, Section 26.7.

### Fastening meets the design criteria!



# Hilti PROFIS Engineering 3.1.9

www.hilti.com

Company: Quantum Consulting Engineers  
 Address: 1511 Third Ave, Suite 323  
 Phone | Fax: 2069573900 |  
 Design: Metal deck - Dec 27, 2024  
 Fastening point:

Page: 6  
 Specifier: Travis Michaud  
 E-Mail: tmichaud@quantumce.com  
 Date: 12/27/2024

## 7 Installation data

Profile: -  
 Hole diameter in the fixture: -  
 Plate thickness (input): -

Drilling method: SafeSet - automatic cleaning  
 Cleaning: Automatically performed while drilling

Anchor type and diameter: KWIK HUS-EZ (KH-EZ)  
 (Carbon Steel) 1/2 (4 1/4)  
 Item number: 418075 KH-EZ 1/2"x4 1/2"  
 Maximum installation torque: 540 in.lb  
 Hole diameter in the base material: 0.500 in.  
 Hole depth in the base material: 4.625 in.  
 Minimum thickness of the base material: 3.250 in.

Hilti  $\varnothing$  1/2 in KWIK HUS-EZ (KH-EZ) (Carbon Steel) with 4.25 in nominal embedment depth per ICC-ES ESR-3027 , SAFEset - automatic cleaning installation per MPII

### 7.1 Recommended accessories

Drilling	Cleaning	Setting
<ul style="list-style-type: none"> <li>Suitable Rotary Hammer</li> <li>Vacuum cleaner</li> </ul>	<ul style="list-style-type: none"> <li>No accessory required</li> </ul>	<ul style="list-style-type: none"> <li>Torque wrench</li> </ul>

### Coordinates Anchor in.

Anchor	x	y	C <sub>-x</sub>	C <sub>+x</sub>	C <sub>-y</sub>	C <sub>+y</sub>
1	0.000	0.000	-	-	-	-



## Hilti PROFIS Engineering 3.1.9

---

[www.hilti.com](http://www.hilti.com)

Company: Quantum Consulting Engineers  
Address: 1511 Third Ave, Suite 323  
Phone | Fax: 2069573900 |  
Design: Metal deck - Dec 27, 2024  
Fastening point:

Page: 7  
Specifier: Travis Michaud  
E-Mail: [tmichaud@quantumce.com](mailto:tmichaud@quantumce.com)  
Date: 12/27/2024

---

### 8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

# P1000 & P1001 Channels

## P1000 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	380	1.14	200	150	100
120	340	1.40	160	120	80
144	280	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

## P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

## P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

## P1001 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,670	15,520	12,390
72	5,620	18,970	16,160	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,250	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

## P1000/P1001 - ELEMENTS OF SECTION

Parameter	P1000	P1001
Area of Section	0.555 In <sup>2</sup>	1.111 In <sup>2</sup>
Axis 1-1		
Moment of Inertia (I)	0.185 In <sup>4</sup>	0.928 In <sup>4</sup>
Section Modulus (S)	0.202 In <sup>3</sup>	0.571 In <sup>3</sup>
Radius of Gyration (r)	0.577 In	0.914 In
Axis 2-2		
Moment of Inertia (I)	0.236 In <sup>4</sup>	0.471 In <sup>4</sup>
Section Modulus (S)	0.290 In <sup>3</sup>	0.580 In <sup>3</sup>
Radius of Gyration (r)	0.651 In	0.651 In

Notes:

\* Load limited by spot weld shear.

\*\* KL/r > 200

NR = Not Recommended.

- Beam loads are given in total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 62 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:
 

"KO" Series.....	95%	"T" Series .....	85%
"HS" Series .....	90%	"SL" Series .....	85%
"H3" Series.....	90%	"DS" Series.....	70%
"WT" Series.....	85%		
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Unipier®



**LATERAL BRACING LOAD REDUCTION CHARTS**

Span		Single Channel										Double Channel											
Ft. (m)	In. (cm)	P1000	P1100	P2000	P3000	P3300	P4000	P4100	P4400	P4520	P5000	P5500	P1001	P1101	P2001	P3001	P3301	P4001	P4101	P4401	P4521	P5001	P5501
2 (0.61)	24 (61)	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
3 (0.91)	36 (91)	0.94	0.89	0.88	0.96	1.00	0.94	0.98	1.00	1.00	0.85	0.89	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
4 (1.22)	48 (122)	0.88	0.78	0.75	0.91	1.00	0.88	0.94	0.98	1.00	0.70	0.77	1.00	0.98	0.98	1.00	1.00	0.98	1.00	1.00	1.00	0.97	0.98
5 (1.52)	60 (152)	0.82	0.68	0.61	0.88	0.98	0.83	0.91	0.96	1.00	0.55	0.67	0.97	0.93	0.92	0.98	1.00	0.93	0.96	1.00	1.00	0.90	0.93
6 (1.83)	72 (183)	0.78	0.59	0.48	0.84	0.97	0.79	0.89	0.94	0.98	0.44	0.58	0.93	0.87	0.85	0.95	0.97	0.88	0.92	0.97	0.97	0.83	0.87
7 (2.13)	84 (213)	0.75	0.52	0.41	0.82	0.96	0.75	0.86	0.92	0.97	0.38	0.51	0.89	0.82	0.78	0.92	0.95	0.83	0.89	0.95	0.95	0.76	0.81
8 (2.44)	96 (244)	0.71	0.47	0.35	0.79	0.94	0.72	0.84	0.91	0.96	0.33	0.46	0.85	0.76	0.71	0.88	0.92	0.79	0.85	0.92	0.92	0.68	0.76
9 (2.74)	108 (274)	0.69	0.43	0.32	0.77	0.93	0.69	0.82	0.89	0.95	0.30	0.42	0.81	0.70	0.64	0.85	0.90	0.74	0.81	0.90	0.90	0.61	0.70
10 (3.05)	120 (305)	0.66	0.40	0.29	0.75	0.92	0.66	0.80	0.87	0.94	0.28	0.40	0.78	0.65	0.57	0.82	0.87	0.69	0.78	0.87	0.87	0.54	0.64
12 (3.66)	144 (366)	0.61	0.36	0.25	0.70	0.89	0.60	0.76	0.84	0.91	0.24	0.36	0.70	0.54	0.45	0.76	0.82	0.60	0.71	0.82	0.83	0.43	0.53
14 (4.27)	168 (427)	0.55	0.32	0.23	0.66	0.86	0.55	0.73	0.81	0.89	0.22	0.32	0.63	0.45	0.38	0.70	0.78	0.51	0.64	0.77	0.78	0.35	0.45
16 (4.88)	192 (488)	0.51	0.30	0.21	0.62	0.84	0.50	0.69	0.78	0.87	0.21	0.30	0.56	0.39	0.32	0.64	0.73	0.44	0.57	0.72	0.73	0.30	0.39
18 (5.49)	216 (549)	0.47	0.28	0.19	0.58	0.81	0.47	0.65	0.75	0.84	0.19	0.28	0.49	0.34	0.28	0.58	0.68	0.39	0.50	0.67	0.68	0.27	0.34
20 (6.10)	240 (610)	0.44	0.26	0.18	0.54	0.78	0.43	0.61	0.72	0.82	0.18	0.26	0.44	0.31	0.25	0.52	0.63	0.35	0.45	0.62	0.63	0.24	0.30

**BEARING LOADS ON UNISTRUT CHANNEL**

Channel	Bearing Length 1 1/8" (41 mm) Maximum Allowable Loads Lbs (kN)		Bearing Length 1 1/8" (41 mm) Maximum Allowable Loads Lbs (kN)		Bearing Length 3/4" (82 mm) Maximum Allowable Loads Lbs (kN)	
	P1000	6,700 29.80	3,100 13.79	7,700 34.25	P1100	3,500 15.57
P2000	2,500 11.12	1,200 5.34	3,000 13.34	P3000	6,700 29.80	7,700 34.25
P3300	6,800 30.25	3,200 14.23	7,800 34.70	P4000	2,600 11.57	3,000 13.34
P4100	3,500 15.57	1,800 8.01	4,100 18.24	P4400	7,300 32.47	8,400 37.37
P4520	7,300 32.47	3,400 15.12	8,400 37.37	P5000	6,500 28.91	7,500 33.36
P5500	6,600 29.36	3,100 13.79	7,600 33.81			

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Unipier®

# Server Unistrut Support Framing

IBC 2021, ASCE 7-16

## 1.) Seismic Parameters

Sds	1.01	<u>Seismic Force Per ASCE 7-16 Chap 13</u>	
h/z	0.33	ap =	1
Server Weight (W)	7000 lb	Rp =	2.5
Server Length	83 in	lp =	1
Server Width	36 in	Fp_Min = 0.3 Sds W	<b>2121 lb</b>
Center of Mass	58 in	Fp_Max = 1.6 Sds W	11312 lb
Min. Servers Per Group	3	Fp = 0.4 Sds (ap W / Rp lp) (1+2*h/z)	
Minimum OT Width	83 in	Fp =	1508 lb

Overtuning Moment	366922 lb-in
Resisting Moment	871500 lb-in
Factor of Safety	2.38 $\geq$ 1.5 OK

ASD Point Load At Unistrut 1032 lb

## 2.) P1000 Unistrut Beams

Number of Supports	4
Unistrut Span	24 in
DL At Support	1167 lb
DL+0.7 EQ At Support	1854 lb
P1000 Capacity	1690 lb
Uc EQ =	1.10 $\leq$ 1.33 OK per engineering judgement
Uc DL =	0.69 $\leq$ 1.00 OK

## 3.) Double P1001 Unistrut Beams

DL+0.7 EQ At Support	4532 lb (Assuming server support aligns over girder)
Unistrut Span	48 in
(2) P1001 Capacity	4780 lb
Uc EQ =	0.95 $\leq$ 1.0 OK



Quantum Consulting Engineers LLC  
1511 Third Avenue, Suite 323  
Seattle, WA 98101

Project: **Centeris**  
Client: **Centeris**

Date: **12/27/24** Job No: **23444.01**  
Designer: **TVM** Sheet: **1**  
Checked: