



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 28, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRDB20241780

Property Address: 1715 E MAIN, PUYALLUP, WA 98372;

Contractor: SOUND ENTERPRISES PO BOX 923 AUBURN, WA 98092 (253) 347-4569

To construct: Repairs from car damage to detached garage structure - RIVER TRAIL APT'S

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; straps complete at top plate breaks. (ok to install exterior sheathing)
 - 2 ; complete install of all holdowns with galvanized plate washers.
 - 3; seal penetration in top plates at electrical penetrations to complete firestop.
 - 4 ; tighten nuts at front garage wall at simpson HDU holdowns.
 - 5 ; provide electrical cover approval prior to frame inspection.
- not ready

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684