



January 27, 2025

City of Puyallup
Building Division
Permit Center
333 S. Meridian
Puyallup, WA 98371

RE: Responses to Correction Letter Comments
Centeris Voltage Park
1015-1023 39th Avenue S.E., Puyallup, WA 98374
City File No. PRRWF20241913
Our Job No. 18111

We have revised the plans and technical documents for the above-referenced project in accordance with your comment letter dated January 21, 2025. Enclosed are the following documents for your review and approval:

1. Revised Wall Site Plan dated January 27, 2025

The following outline provides each of your comments in italics exactly as written, along with a narrative response describing how each comment was addressed:

Engineering Review | Yianni Charitou | (253) 435-3612 | ycharitou@puyallupwa.gov

1. *Depict and label the proposed 4" perforated rigid PVC pipe footing drain at the base of the wall that is designed by others. Label the wall footing drain discharge location and its connection to the proposed stormwater system. [SITE PLAN, sheet C15]*

Response: The 4-inch wall drain has been added to the plan with the discharge location shown.

2. *Provide the site address and tax parcel number on the retaining wall site plan. [SITE PLAN, sheet C15]*

Response: The site address and parcel number has been added to the plan.

We believe that the above responses, together with the enclosed revised plans and technical documents, address all of the comments in your letter dated January 21, 2025. Please review and approve the enclosed at your earliest convenience. If you have questions or need additional information, please do not hesitate to contact me at this office. Thank you.

Sincerely,

Cara Visintainer, P.E.
Senior Civil Project Manager

CV/kb
18111c.011.docx
enc: As Noted
cc: