



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

David Vranizan
9675 SE 36th Street, Suite 115
Mercer Island, WA 98040

January 27, 2025

Notice of Incomplete Permit Submittal

RE: Application Number PRCTI20250117

Dear David Vranizan,

A permit application has been received by this office on January 24, 2025. The following required items are outstanding:

- **Application Form:** Make sure the entire form is completed, signed, and dated. The form can be located [here](#).
- **Construction Plan Set:** Provide structural plans showing the overall structure and the extent of the work, the locations of all new or revised structural elements, etc. The structural plans will need to be stamped and signed by the engineer of record. The calculations also specify an allowable soil-bearing pressure of 5,000 psf. We'll need the supporting geotechnical report to **confirm that value**.

The above information must be received by our office to deem this application complete. If the required information is not received within 90 days, your application will be canceled.

Should you require further information, please do not hesitate to contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1