



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 29, 2025

**Inspection Result:**

**PASSED W/  
CONDITIONS**

**Permit Number:** PRCTI20241072

**Property Address:** 4102 S MERIDIAN, Unit: D, PUYALLUP, WA 98373;

**Contractor:** POWELL CONSTRUCTION COMPANY 2625 NORTHUP WAY BELLEVUE, WA 98004

**To construct:** NEW ENTRY FACADE/FEATURE FOR EXISTING RETAIL SPACE (#10), ALONG WITH NEW FULL-HEIGHT DEMISING WALL, NEW SEWER AND WATER LINES ALONG WITH ELECTRICAL RUNS (ALL TO BE CAPPED AT LOCATION OF FUTURE NEEDS). PREPPING SPACE FOR NEW TENANT (BY OTHERS) WHO WILL HAVE THEIR OWN TI PERMIT FOR ALL INTERIOR WORK.

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Conditions for north TI!

When performing the north side TI and sewer extension please remove the concrete around the south three sewer c/o's to install the 8" sleeve.

All four sewer c/o's need to have an 8" pipe installed around them, then set the casting over the pipe.

The gravel will fall into the sewer when accessing the lid.

Please see City of Puyallup detail 02.01.09

**Corrections:**

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little  
Development Engineering Inspector  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 244-0387