



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 30, 2025

Inspection Result: NOT READY

Permit Number: PRMU20240401

Property Address: 801 SHAW RD BLDG D, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING D 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER -ETC – APT BLDG D

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide special inspection report at time of footing inspection.
- 2 ; ground frozen at time of footing inspection, call for inspection after ground is thawed.
- 3 ; provide geo-tech approval letter for soil bearing requirement of 1,500 psf as required per E.O.R. as noted on city approved plans.
- not ready - cancel per contractor.
- 2 ground still frozen- cancel per contractor

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684