



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 30, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCNC20241019

**Property Address:** 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

**Contractor:** MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA 98409

**To construct:** Construct Early Learning Center

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 1 ; ok to pour with special inspection approval report. ( except at areas blocked out for sewer relocation as discussed with contractor.)

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684