



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 31, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20230970

Property Address:

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1/30 - JL - McKee was able to pressurize the fire line for building "B".

- Pressure tested the fire line for building "B" from the main 6"GV through the PIV, through the DDCVA, to the FDC (removing the flapper), and to the building flange at 200psi for 2hrs with zero drop. (PASSED)

- Flushed the fire line through the FDC first due to lack of hoses. Flushed through 2-2.5" hoses for 15min twice. (PASSED) Note: Found cardboard throughout flushing!

- Flushed the fire line through the building flange (installed flapper on the swing check to block FDC). Flushed through 2-2.5" hoses for 15min 4 times. (PASSED) Note: found cardboard throughout flush!

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387