



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 31, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20241123

Property Address: 105 7TH ST SW, PUYALLUP, WA 98371; 711 W MAIN, PUYALLUP, WA 98371;

Contractor: STREAMLINE GENERAL CONSTRUCTION LLC 1006 208TH AVE E LAKE TAPPS, WA 98391

To construct: On site civil grading, walkway modifications and additions, and stormwater system being installed for the addition of 3 double classroom portable buildings. Per zoning code requirement Frontage planting buffer improvements are included. Offsite related improvements to be submitted separately. This permit application is related to individual portable building permits PRPF 20241042, PRPF 20241043, PRPF 20241044 and CUP PLCUP 20230109.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: They are ready for a punch list.
See corrections.

Corrections:

1. Storm inspection port cover lids need the "SEWER" removed from all of them.
2. Call me to schedule a site visit to inspect the CB tee screen install.
3. Need to schedule a planning inspection for the lawn soil amendment. It appears that the hydro seed was applied over wood chips and not amended.
4. Please see condition items 12 & 15.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387