



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Feb 10, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20241123

**Property Address:** 105 7TH ST SW, PUYALLUP, WA 98371; 711 W MAIN, PUYALLUP, WA 98371;

**Contractor:** STREAMLINE GENERAL CONSTRUCTION LLC 1006 208TH AVE E LAKE TAPPS, WA 98391

**To construct:** On site civil grading, walkway modifications and additions, and stormwater system being installed for the addition of 3 double classroom portable buildings. Per zoning code requirement Frontage planting buffer improvements are included. Offsite related improvements to be submitted separately. This permit application is related to individual portable building permits PRPF 20241042, PRPF 20241043, PRPF 20241044 and CUP PLCUP 20230109.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Please work with COP review engineer and planning to resolve the conditions.

**Corrections:**

- 1 1. Need to schedule a planning inspection for the lawn soil amendment. It appears that the hydro seed was applied over wood chips and not amended.
2. Please see condition items 12 & 15.

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little  
Development Engineering Inspector  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 244-0387