



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Feb 10, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20241053

**Property Address:** 310 31ST AVE SE, PUYALLUP, WA 98374;

**Contractor:** SLETTEN CONSTRUCTION COMPANY PO BOX 2467 GREAT FALLS, MT 59403

**To construct:** General remodel to existing Walmart store. Interior updates include mechanical, electrical, plumbing, and cosmetic changes. Minor updates to exterior site. ~ WALMART INTERIOR REMODEL

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Courtesy walk with our Sletten PM and Walmart CM not on-site at time of am ceil grid inspection.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684