



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 10, 2025

Inspection Result: NOT READY

Permit Number: PRMU20240404

Property Address: 2902 E PIONEER, BUILDING G, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER - APT BLDG G * REVISION (1) - 1/30/2025 - ENGINEERED
TRUSS DRAWINGS

On this day we have inspected your construction for **Shear Wall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: not ready

Corrections:

- 1 Bottom plate nailing approved per special inspection.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684