



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 12, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20240232

Property Address: 201 5TH AVE NE, PUYALLUP, WA 98372;

Contractor: DOCE LLC PO BOX 64160
TACOMA

To construct: Site development for proposed apartments (This permit submittal replaces permit PRCCP20220417 due to design changes & new civil construction permit needed per Ken Cook).

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Contractor is working on the 2" service and 3/4" irrigation. They are also trying to perform hydrotesting on the PIV stub.

Hydro-test PIV from PIV GV to 6"GV at the main for 2hrs @ 200psi (PASSED).

Hydro-tested east hydrant from 6"GV at the main through hydrant for 2hrs @ 200psi (PASSED).

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 244-0387