



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 13, 2025

Inspection Result:

**PASSED W/
CONDITIONS**

Permit Number: PRMU20240401

Property Address: 801 SHAW RD BLDG D, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING D 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER -ETC – APT BLDG D

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete install of missing holdowns.
- 2 ; provide min. bar lap as discussed with contractor.
- 3 ; provide special inspection approval prior to concrete placement.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org