

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Feb 15, 2025	Inspection Result:	PASSED
Permit Number: Property Address:	PRMH20240593 1023 39TH AVE SE, PUYA	ALLUP, WA 98374;	
Contractor:	HERMANSON 1221 2ND AVE N KENT, WA 98032		
To construct:	Phase 2 build-out of existing chilled water plant. Scope includes		
	installation of the following fixtures: (1) Water Cooled Chiller and (1)		
	Chilled water pump, (1) Cooling Tower and Condenser Water Pump, (1)		
	Buffer Tank, and (1) Solid Separator. To include piping connections		
	between new equipment to existing system.		

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved test at 100 psi at heat exchanger #2

Corrections:

Sincerely,

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684

King