



City of Puyallup – Fire Prevention Department

Application for Fire Code – Construction Permit

333 S. Meridian
Puyallup, WA 98371
Tel: (253) 864-4165

Building Permit # (in association to the fire sprinkler/alarm submittal)

Parcel #: 0419034037	Site Address: 1023 39th AVE SE, Puyallup, WA 98374
Owner Name: South Hill Business & Tech Centeris Data Center	Phone #: 425-241-7676
Owner Address: 1023 39th Ave SE	City: Puyallup Zip: 98374
Contractor Name: Convergent Technologies	Phone #: 425-272-2500
Contractor Address: 450 Shattuck Ave S Suite 100	City: Renton Zip: 98057
WA License #: CONVETL984BQ	Exp. Date: 01/18/2026 City Business License #: 2003257
Contact Person: Charity Powers	Contact Email Address: charity.powers@convergent.com
Contact Phone #: 206-258-0521	Contact Fax #:

PROJECT DESCRIPTION (TO INCLUDE TENANT NAME):

DDC room on 1st floor has increased by (55 s.f). Extending the VESDA aspiration piping to cover this area from existing VESDA unit. Work is the extension of the pipe only. CENTERIS VOLTAGE PARK

THE APPLICANT HEREBY MAKES APPLICATION FOR THE FOLLOWING FIRE CODE PERMIT

Permit	Description	# of Devices or square footage	Notes/Requirements
<input type="checkbox"/> Fire Sprinkler – New	Installation of a New Automatic Fire Sprinkler System		Total square footage of fire sprinkler required
<input type="checkbox"/> Fire Sprinkler – Tenant Improvement	Tenant Improvement to Existing Fire Sprinkler System		
<input type="checkbox"/> Fire Alarm System -New	Installation of a New Fire Alarm System		Designed to total coverage NFPA72
<input checked="" type="checkbox"/> Fire Alarm System - Tenant Improvement	Tenant Improvement to Existing Fire Alarm System	55	Designed to total coverage NFPA72
<input type="checkbox"/> Hood Suppression	New or modification of existing system		
<input type="checkbox"/> Generator	Backup Generator or Emergency Generator - \$265		
<input type="checkbox"/> OTHER			

***Selection Below Must Be Completed By Applicant ~ **Please Acknowledge BOTH REQUIRED** ***

- ☒ U.L. Certification/Third Party Acknowledgement (check box for acknowledgment)
- ☒ NICET Level of Fire Alarm Designer Acknowledgment (check box for acknowledgment)

I have submitted a minimum of three sets of plans and calculations/cut sheets

Signature:

Date:

Print Signature:

Charity Powers

Email:

charity.powers@convergent.com