



STRUCTURAL CALCULATIONS

FOR

MHS GOOD SAMARITAN HOSPITAL
X-RAY EQUIPMENT REPLACEMENT
401 15TH AVE SE
PUYALLUP, WA 98372

PREPARED BY
PCS STRUCTURAL SOLUTIONS



DECEMBER 16, 2024
25-078

Calculations required to be provided by
the Permittee on site for all Inspections

GOOD SAM HOSPITAL X-RAY AND IR ROOM EQUIPMENT Replacement

The purpose of these calculations is to

- 1. Demonstrate that the anchorage and support for Imaging detector, Patient table and their system components are structurally adequate.*
- 2. Verify Existing Structure can support the proposed equipment*

Design Criteria (IBC 2018)

Risk Category: IV
 Site Class: D(From GeoReport)
 Short-Period Response Coefficient: $S_{DS} := 1.013$



Seismic

Site Soil Class: D - Default (see Section 11.4.3)

Results:

S_S :	1.267	S_{D1} :	N/A
S_1 :	0.436	T_L :	6
F_a :	1.2	PGA :	0.5
F_v :	N/A	PGA _M :	0.6
S_{MS} :	1.52	F_{PGA} :	1.2
S_{M1} :	N/A	I_e :	1.5
S_{DS} :	1.013	C_v :	1.353





ASCE Hazards Report

Address:
401 15th Ave SE
Puyallup, Washington
98372

Standard: ASCE/SEI 7-16
Risk Category: IV
Soil Class: D - Default (see
Section 11.4.3)

Latitude: 47.178536
Longitude: -122.290015
Elevation: 132.37311568935164 ft
(NAVD 88)



Site Soil Class: D - Default (see Section 11.4.3)

Results:

S_S :	1.267	S_{D1} :	N/A
S_1 :	0.436	T_L :	6
F_a :	1.2	PGA :	0.5
F_v :	N/A	PGA _M :	0.6
S_{MS} :	1.52	F_{PGA} :	1.2
S_{M1} :	N/A	I_e :	1.5
S_{DS} :	1.013	C_v :	1.353

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

Data Accessed: Wed Nov 27 2024


Date Source: [USGS Seismic Design Maps](#)

The ASCE Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE Hazard Tool.

Overview of New Equipment X-RAY ROOM (Level 1)



EQUIPMENT LEGEND							
NO	DESCRIPTION	SMS SYM	WEIGHT (LBS)	BTU/HR TO AIR	DIMENSIONS (INCHES)		
					W	D	H
1	CONTROL MODULE	2	-	4 3/4	10	2 3/4	
2	LED TOUCHSCREEN MONITOR	18	205	22 1/2	8 5/8	15 1/4	
3	IMAGING SYSTEM CONTAINER (UNDER COUNTER)	15	1,468	8	21	15	
4	CHARGING STATION FOR MAX DETECTORS	4	-	12 1/2	6 3/4	2	
5	YSIO XPREE TABLE WITH MOBILE DETECTOR	970	2,560	94 13/16	31 1/2	***	
6	FLAT TABLE TOP	-	-	-	-	-	
7	POLYDOROS R80-2 (80 kW) GENERATOR CABINET	944	2,048**	31 1/2	17 1/8	86 3/4	
8	ACCESS POINT (TOP OF GENERATOR)	1	-	5	6 3/8 *	1	
9	YSIO XPREE WALL STAND WITH FIXED DETECTOR (RIGHT LOADING GRID)	496	751	30	35*A	83	
10	4.25M CEILING RAILS FOR X-RAY TUBE SUSPENSION	59	-	167 3/8	3	4	
11	3M YSIO XPREE BRIDGE & X-RAY TUBE STAND	772	853	119 1/4	39	*43	
12	GRID HOLDER (WALL MOUNTED)	22	-	21 11/16	4	16 9/16	
13	MOBILE DETECTOR HOLDER ON WHEELS	121	-	24 1/2	40 3/16	70 1/2	
14	EATON UPS 5P 850G FOR IMAGING SYSTEM ONLY	22	135	6	13 5/8	9 1/4	

By Inspection, they highlighted equipment will require seismic supports


1. YSIO XPREE TABLE WITH MOBILE DETECTOR

Design Forces

Per ASCE 7-16 Chapter 13 - Seismic Design Requirements for Non-Structural Components
Seismic Coefficients per Table 13.6-1, Other Mechanical and Electrical Components:

Component Importance Factor:	$I_p := 1.5$	
Component Amplification Factor:	$a_p := 1.0$	(T13.6-1)
Response Modification Factor:	$R_p := 1.5$	(T13.6-1)
Overstrength Factor:	$\Omega := 2.0$	(T13.6-1)
Building Height:	$H := 146 \text{ ft}$	
Height of Attachment:	$z := 0 \text{ ft}$	Anchor to S.O.G.
Calculated Horizontal Force Coefficient:	$f_p := \frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p}\right)} \cdot \left(1 + 2 \cdot \frac{z}{H}\right) = 0.405$	(13.3-1)
Maximum Horizontal Force Coefficient:	$f_{pmax} := 1.6 \cdot S_{DS} \cdot I_p = 2.43$	(13.3-2)
Minimum Horizontal Force Coefficient:	$f_{pmin} := 0.3 \cdot S_{DS} \cdot I_p = 0.46$	(13.3-3)
Governing Horizontal Force Coefficient:	$f_p := \min(f_{pmax}, \max(f_p, f_{pmin})) = 0.46$	
Vertical Force Coefficient:	$f_{pv} := 0.2 \cdot S_{DS} = 0.203$	
Total Weight:	$W_p := 1675 \text{ lbf}$	include 660lb patient weight
Design Force (Horizontal):	$F_p := f_p \cdot W_p = 764 \text{ lbf}$	
Design Force (Vertical):	$F_{pv} := f_{pv} \cdot W_p = 339 \text{ lbf}$	

Check seismic anchorage



Anchor Bolt Tension

Vertical Distance to C.G.:

$$Z_{cm} := 30 \cdot \text{in}$$

X1:

$$X1 := 4.5 \cdot \text{in}$$

X2:

$$X2 := 9.25 \cdot \text{in}$$

Sum moment at thee lower left corner:

$$\text{Total Tension (0.9DL - E): } T := \frac{(\Omega \cdot F_p \cdot Z_{cm}) - (0.9 \cdot W_p - F_{pv}) \cdot X1}{X1 + X2} = 2950 \text{ lbf}$$

Bolts Resisting Overturning:

$$n := 2$$

Tension/Bolt(Uplift):

$$T_b := \frac{T}{n} = 1475 \text{ lbf}$$

Anchor Bolt Shear

Shear/Bolt:

$$S_b := \frac{\Omega \cdot F_p}{2 n} = 382 \text{ lbf}$$

See Hilti Analysis: Use (4) 5/8"Ø Kwik Hus EZ (Concrete Screw)with 3.0" Embed

2. Generator Cabinet

Design Forces

Component Importance Factor: $I_p := 1.5$

Component Amplification Factor: $a_p := 1.0$ (T13.6-1)

Response Modification Factor: $R_p := 1.5$ (T13.6-1)

Overstrength Factor: $\Omega := 2.0$ (T13.6-1)

Building Height: $H := 146 \text{ ft}$

Height of Attachment: $z := 0 \text{ ft}$ Anchor to First Floor

Calculated Horizontal Force Coefficient: $f_p := \frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p}\right)} \cdot \left(1 + 2 \cdot \frac{z}{H}\right) = 0.405$ (13.3-1)

Maximum Horizontal Force Coefficient: $f_{pmax} := 1.6 \cdot S_{DS} \cdot I_p = 2.43$ (13.3-2)

Minimum Horizontal Force Coefficient: $f_{pmin} := 0.3 \cdot S_{DS} \cdot I_p = 0.46$ (13.3-3)


Governing Horizontal Force Coefficient: $f_p := \min(f_{pmax}, \max(f_p, f_{pmin})) = 0.46$

Vertical Force Coefficient: $f_{pv} := 0.2 \cdot S_{DS} = 0.203$

Total Weight: $W_p := 1102 \text{ lbf}$

Design Force (Horizontal): $F_p := f_p \cdot W_p = 502 \text{ lbf}$



Design Force (Vertical): $F_{pv} := f_{pv} \cdot W_p = 223 \text{ lbf}$



See Hilti Analysis: Use (2) 3/8"Ø Concrete Screw with 3" Embed, one at each side of the generator cabinet

Thickness (Mils)	Design Thickness
18	0.018
27	0.027
30	0.030
33	0.033
43	0.043
54	0.054
68	0.068
97	0.097
118	0.118
54	0.054
68	0.068
97	0.097
118	0.118

3. TSIO XPREE WALL STAND



Design Forces

Component Importance Factor: $I_p := 1.5$

Component Amplification Factor: $a_p := 2.5$

Response Modification Factor: $R_p := 2.5$

Overstrength Factor: $\Omega := 2.0$

Building Height: $H := 146 \text{ ft}$

Height of Attachment: $z := 0 \text{ ft}$ Anchor to 1 Floor

Calculated Horizontal Force Coefficient: $f_p := \frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p}\right)} \cdot \left(1 + 2 \cdot \frac{z}{H}\right) = 0.608$

Maximum Horizontal Force Coefficient: $f_{pmax} := 1.6 \cdot S_{DS} \cdot I_p = 2.43$

Minimum Horizontal Force Coefficient: $f_{pmin} := 0.3 \cdot S_{DS} \cdot I_p = 0.46$

Governing Horizontal Force Coefficient: $f_p := \min(f_{pmax}, \max(f_p, f_{pmin})) = 0.61$

Vertical Force Coefficient: $f_{pv} := 0.2 \cdot S_{DS} = 0.203$

Total Weight:

$$W_p := 661 \text{ lbf}$$

Design Force (Horizontal):

$$F_p := f_p \cdot W_p = 402 \text{ lbf}$$

Design Force (Vertical):

$$F_{pv} := f_{pv} \cdot W_p = 134 \text{ lbf}$$

Anchor Bolt Tension

Sum moment at lower right point of the elevation view:

Vertical Distance to C.G.:

$$Z_{cm} := 47 \text{ in}$$

C.O.G to wall:

$$X1 := 8 \text{ in}$$

Anchor Spacing:

$$S := 10.125 \text{ in}$$

$$T := \frac{(\Omega \cdot F_p \cdot Z_{cm})}{S} = 3730 \text{ lbf}$$

Anchor Resisting:

$$n := 2$$

Tension/anchor:

$$T_b := \frac{T}{n} = 1865 \text{ lbf}$$



Anchor Bolt Shear

Shear/Bolt(assume resist by floor support 100%):


$$S_b := \frac{\Omega \cdot F_p}{4} = 201 \text{ lbf}$$

See Hilti Analysis: Use (2) 5/8"Ø Concrete Screw with 3" Embed, one at each side of the generator cabinet

California Department of Health Care have done testing on those equipment, which indicates the weight of 803 lb

UUT-1	UNIT UNDER TEST (UUT) SUMMARY SHEET					
Mounting Details: Rails and connecting parts of the 3D Tube Stand bolt with M10 bolts torqued at 36 ft-lb to unistrut grid spaced at 26.6" on center. The unistrut grid consisted of MURPO#150969 MPR-41/82.2.0 I Profiles (Unistrut P1001 equivalent) anchored with 2 - M10 bolts with clamping claws (MURPO 157219) at each intersection to the ceiling fixture framing spaced at 23.6" on center.						
						
Manufacturer: Siemens Healthcare GmbH	Test Location: 1ABG - Munich, Germany					
Component: Carriage 3D 3m manual Tube stand 3D V semi motorized	Test Date: September 2020					
Model Number: 07042091	Report Number: TAB3-PB-20-134-V1					
UUT Function: X-Ray stand, ceiling suspended, to be used in radiography imaging, fully automated						
UUT Description: Component of the YSIO X prece X-Ray System						
UUT PROPERTIES						
Weight (lb)	Dimensions (inches)			Natural Frequency (Hz)		
	Width	Depth	Height	FB	SS	V
803	119	167	33-104	N/A	N/A	N/A
The ceiling suspended stand moves laterally, rotates, and extends up and down to accommodate different patients and procedures. The system was tested in the normal operating position with the system horizontally centered, no rotation, and with a downward extension of 32in (height = 33in + 32in = 65in).						


The new equipment has a similar weight of 846lb :



ELEVATION

$$\frac{846 \text{ lbf} - 803 \text{ lbf}}{803 \text{ lbf}} = 5.35\%$$

by inspection, the existing support should carry the new equipment gravity-wise



Seismic Design Forces for automated Bridge:

Per ASCE 7-16 Chapter 13 - Seismic Design Requirements for Non-Structural Components
 ASCE 7-16 T13.5-1 for flexible components w/ high deformability

Component Importance Factor: $I_p = 1.5$

Component Amplification Factor: $a_p := 2.5$ (T13.6-1)

Response Modification Factor: $R_w := 25$ (T13.6-1)

Overstrength Factor: $\Omega := 2.5$ (T13.6-1)

Building Height: $H := 146 \text{ ft}$

Height of Attachment: $z := 12 \cdot \text{ft}$

Horizontal Force Coefficient: $f_p := \frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p}\right)} \cdot \left(1 + 2 \cdot \frac{z}{H}\right) = 0.071$ (13.3-1)

$f_{pmax} := 1.6 \cdot S_{DS} \cdot I_p = 2.43$ (13.3-2)

$f_{pmin} := 0.3 \cdot S_{DS} \cdot I_p = 0.46$ (13.3-3)

Governing Horizontal Force Coefficient: $f_p := \min(f_{pmax}, \max(f_p, f_{pmin})) = 0.46$

Vertical Force Coefficient: $f_{pv} := 0.2 \cdot S_{DS} = 0.203$

Forces

Equipment Properties

Seismic Weight: $W := (846 + 59 + 59) \text{ lbf}$

Seismic Design Forces

Horizontal Seismic Force: $F_p := f_p \cdot W = 439 \text{ lbf}$

Vertical Seismic Force: $F_{pv} := 0.2 \cdot S_{DS} \cdot W = 195 \text{ lbf}$

By information provided from Sellen, the contractor, the vertical hanger is constructed with 1/2" threaded rod, spaced @ 4'-0" O.C. max

The unistrut above the ceiling are P1001

$$P := 846 \text{ lbf} \cdot 1.0 \quad L := 48 \text{ in} \quad \text{ASD}$$

$$M := \frac{P \cdot L}{4} = (1.015 \cdot 10^4) \text{ in} \cdot \text{lbf}$$

Less than the allowable moment provided in Unistrut Catalog

CHANNELS & COMBINATIONS IN DESCENDING ORDER OF STRENGTH


Channel	Area in ² (cm ²)	Weight lbs/ft (kg/m)	I in ⁴ (cm ⁴)	s in (cm)	Allow. Moment in-lbs (N·m)
P5001	1.793 11.57	6.10 9.1	6.227 259.2	1.916 31.4	48,180 5,440
P1004A	1.965 12.68	6.68 9.9	4.068 169.3	1.669 27.4	41,980 4,740
P5501	1.452 9.37	4.94 7.3	2.805 116.8	1.151 18.9	28,940 3,270
P1001C41	2.221 14.33	7.55 11.2	1.856 77.2	1.142 18.7	28,720 3,250
P5000	0.897 5.78	3.05 4.5	1.098 45.7	0.627 10.3	15,770 1,780
P1001	1.111 7.16	3.78 5.6	0.928 38.6	0.571 9.4	14,360 1,620
P1101	0.835 5.39	2.84 4.2	0.733 30.5	0.451 7.4	11,340 1,280
	1.000	3.40	0.501	0.430	10,810

also compare it with the beam loading table

P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630

10. Continuous Beam, Two Equal Spans,
Concentrated Load at Center of One Span



.62

.71

$$2390 \text{ lbf} \cdot 0.62 = (1.482 \cdot 10^3) \text{ lbf}$$

The demand, 846 lbf are much less than the allowable point load

$$0.13 \text{ in} \cdot 0.71 = 0.092 \text{ in}$$

$$\frac{48 \text{ in}}{0.092 \text{ in}} = 521.739 \quad \text{Deflection acceptable}$$

Recall lateral force

$$F_p = 439.439 \text{ lbf}$$


$$\alpha := 60 \text{ deg}$$

α is between 40-60deg by inspection, 60deg will result the max horizontal force, while 40 will result max length. use the max of both for conservative

$$F_{\text{Brace}} := \frac{F_p}{2 \cdot \cos(\alpha)} = 439.439 \text{ lbf}$$

two braces at each side

DETAIL 5A.1-1: TYPICAL FITTING CONNECTION TO STRUT



Brace fitting acceptable

Table 5a.1-1					
Bolt Size	Installation Torque (ft-lbs)	Max. Capacity (lbs) [ASD]	Maximum Horizontal Fp Force (lbs) [ASD]		
		Pull-Out	Slip Resistance ^c	Perpendicular Brace Side	Perpendicular ^d Opposite Brace
1/2"	50 - 55	2,810	1,370	1,035	640

Story height=15ft

Ceiling to slab above= 4ft

$$\alpha := 40 \text{ deg}$$

$$L_{\text{brace}} := \frac{4 \text{ ft}}{\sin(\alpha)} = 74.675 \text{ in}$$

P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

P1000 Brace OK.

Contractor to verify (2) brace min.
 at each runs of unistrut p1001

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Concrete - Nov 27, 2024

Page:

Specifier:

E-Mail:

Date:

1

12/14/2024

Specifier's comments:

1 Input data

Anchor type and diameter:**KWIK HUS-EZ (KH-EZ) (Carbon Steel) 5/8 (4)**

Item number:

418080 KH-EZ 5/8"x5 1/2"

Specification text:

Hilti \varnothing 5/8 in KWIK HUS-EZ (KH-EZ) (Carbon Steel) with 4 in nominal embedment depth per ICC-ES ESR-3027, Hammer drilled installation per MPII

Effective embedment depth:

 $h_{ef,act} = 3.030$ in., $h_{nom} = 4.000$ in.

Material:

Carbon Steel

Evaluation Service Report:

ESR-3027

Issued | Valid:

12/1/2023 | 12/1/2025

Proof:

Design Method ACI 318-19 / Mech

Shear edge breakout verification:

Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)

Stand-off installation:

Profile:

Base material:


cracked concrete, 2500, $f'_c = 2,500$ psi; $h = 6.000$ in.**Installation:****Hammer drilled hole, Installation condition: Dry**

Reinforcement:

tension: not present, shear: not present; no supplemental splitting reinforcement present
edge reinforcement: none or < No. 4 bar

www.hilti.com			Page:	2
Company:			Specifier:	
Address:			E-Mail:	
Phone Fax:			Date:	12/14/2024
Design:	Concrete - Nov 27, 2024			
Fastening point:				

Geometry [in.] & Loading [lb, in.lb]





www.hilti.com

Company:		Page:	3
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - Nov 27, 2024	Date:	12/14/2024
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1,500; V _x = 0; V _y = 382; M _x = 0; M _y = 0; M _z = 0;	no	52



www.hilti.com

Company:		Page:	4
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - Nov 27, 2024	Date:	12/14/2024
Fastening point:			

2 Proof I Utilization (Governing Cases)

		Design values [lb]		Utilization	Status
Loading	Proof	Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	1,500	2,914	52 / -	OK
Shear	Pryout Strength	382	6,276	- / 7	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.515	0.061	5/3	35	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!



www.hilti.com

Company:		Page:	5
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - Nov 27, 2024	Date:	12/14/2024
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
TSIO XPREE WALL STAND

Page:

Specifier:

E-Mail:

Date:

1

12/14/2024

Specifier's comments:

1 Input data

Anchor type and diameter:**KWIK HUS-EZ (KH-EZ) (Carbon Steel) 5/8 (4)**

Item number:

418080 KH-EZ 5/8"x5 1/2"

Specification text:

Hilti \varnothing 5/8 in KWIK HUS-EZ (KH-EZ) (Carbon Steel) with 4 in nominal embedment depth per ICC-ES ESR-3027 , Hammer drilled installation per MPII

Effective embedment depth:

 $h_{ef,act} = 3.030$ in., $h_{nom} = 4.000$ in.

Material:

Carbon Steel

Evaluation Service Report:

ESR-3027

Issued | Valid:

12/1/2023 | 12/1/2025

Proof:

Design Method ACI 318-19 / Mech

Shear edge breakout verification:

Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)

Stand-off installation:

Profile:

Base material:


cracked concrete, 2500, $f'_c = 2,500$ psi; $h = 6.000$ in.**Installation:****Hammer drilled hole, Installation condition: Dry**

Reinforcement:

tension: not present, shear: not present; no supplemental splitting reinforcement present
edge reinforcement: none or < No. 4 bar

www.hilti.com			Page:	2
Company:			Specifier:	
Address:			E-Mail:	
Phone Fax:			Date:	12/14/2024
Design:	TSIO XPREE WALL STAND			
Fastening point:				

Geometry [in.] & Loading [lb, in.lb]





www.hilti.com

Company:		Page:	3
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	TSIO XPREE WALL STAND	Date:	12/14/2024
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1,865; V _x = 0; V _y = 200; M _x = 0; M _y = 0; M _z = 0;	no	65

www.hilti.com

Company:		Page:	4
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	TSIO XPREE WALL STAND	Date:	12/14/2024
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	β_N / β_V [%]	Status
Tension	Concrete Breakout Failure	1,865	2,914	65 / -	OK
Shear	Pryout Strength	200	6,276	- / 4	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.640	0.032	5/3	48	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!



www.hilti.com

Company:		Page:	5
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	TSIO XPREE WALL STAND	Date:	12/14/2024
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.