



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

**PRDK20241952**

# Permit Review Correction Letter

**Permit Application #PRDK20241952**

January 03, 2025

**February 7, 2025**


***CDA Response in bold italics***

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

## Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Stan Kinnear		SKinnear@puyallupwa.gov
<p>- Provide specifics of the plywood that will be installed which should include plywood thickness, grade and any other specifics that will reflect that the plywood will withstand the dead and live loads of the deck. Identify the non-slip surface that will either be provided on the plywood or will be added to the plywood as part of construction, as notated on sheet A1.0, Owner/Contractor Coordination Notes.</p> <p><b><i>CDA Response: The plywood replacement data which included slip resistance information and span chart for live &amp; dead loads is attached to this response memo.</i></b></p> <p>The existing joist spacing should also be considered when selecting the plywood material that will be used. Please provide the existing joist spacing.</p> <p><b><i>CDA Response: Existing joist spacing is 16" o.c. max.</i></b></p> <p>Updated all details and notes as needed to reflect the requested information.</p> <p><b><i>CDA Response: Details updated with information as required.</i></b></p> <p>(Construction Plans, Sheet A1.1)</p> <p>- Determine the minimum required specifications for deck beams, posts, post bases, post caps and footings if replacements are necessary. Given the work already completed and the stop-work order in place, establish a clear benchmark to assess the completed work and provide clarity for future construction and inspection, minimizing any potential ambiguities.</p> <p><b><i>CDA Response: No deck beam, post or footing replacement is necessary. Existing photos have been added to A1.0 to document existing conditions to date for future inspections.</i></b></p> <p>(Construction Plans, Sheet A1.1)</p> <p>- Deck joists appear to be sloped to drain off of the cantilevered side of each deck based upon details 1 and 2. Detail 2 shows the installation of the 1x6 cedar board over the existing 2x2 balusters. detail or notate how the 1x6 cedar will be installed to prevent drainage and water accumulation on the deck surface.</p> <p><b><i>CDA Response: There will be a space between the existing 2x2 pickets for water to drain off deck.</i></b></p> <p>(Construction Plans, Sheet A1.1)</p> <p>- Add a notation on either Sheet A1.0 or A1.1 that contractor shall verify the integrity of balusters prior to the installation of the 1x6 cedar. Establish the parameters of the balusters replacement to include type, grade and nailing pattern.</p> <p><b><i>CDA Response: Note added to details to review integrity of existing 2x2 pickets and replace with like materials and fasteners.</i></b></p>			



<b>Engineering Review</b>	<b>Adam Hunt</b>	<b>(253)841-5577</b>	<b>AHunt@PuyallupWA.gov</b>
---------------------------	------------------	----------------------	-----------------------------

- Place street names on site plan. [SITE PLAN]

***CDA Response: Street names have been added to the site map.***

- Revise the site plan to depict the new or existing public utility connections (i.e. water, sewer, stormwater) from the public right-of-way to the building(s). The sanitary side sewer connection should include the location of any sewer clean outs, the water connection should include the location of the meter boxes and backflow prevention devices, and the stormwater connection should include the location of any clean outs and onsite stormwater systems.

***CDA Response: No existing survey or as-built information was available to document the existing utilities at the site. We have added a note to the contractor to determine the exact location of all existing utilities before commencing work and to be fully responsible for any damage that may occur.***

## Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center  
(253) 864-4165 option 1  
[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)

**Casey+DeChant Architects LLC**



**Larry DeChant – Architect**

**(253) 677-0364**