



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 04, 2025

Inspection Result: **FAILED**

Permit Number: PRMU20240405

Property Address: 2902 E PIONEER, BUILDING H, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING H 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER – APT BLDG H * REVISION (1) - 2/19/2025 - ENGINEERED
TRUSS DRAWINGS

On this day we have inspected your construction for **Shear Wall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete install of exterior sheathing, install of straps and missing holdowns as per city approved plans.
- 2 ; provide special inspection approved prior to reinspection.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org