

MATRIX
NOT TO SCALE



SYSTEM INPUTS	
1	Building A FACP Smoke Detector
2	Building A Residential
3	Building A Commercial
4	Building B
5	Building C
6	Building D
7	Building E
8	Building F
9	Building G
10	Building H
11	Building J
12	Building K
13	Building L
14	Building M
15	Building N
16	Dry-Flow Switch - Building A
17	Wet-Flow Switch - Building B
18	Wet-Flow Switch - Building C
19	Wet-Flow Switch - Building D
20	Wet-Flow Switch - Building E
21	Wet-Flow Switch - Building F
22	Wet-Flow Switch - Building G
23	Wet-Flow Switch - Building H
24	Wet-Flow Switch - Building J
25	Wet-Flow Switch - Building K
26	Wet-Flow Switch - Building L
27	Wet-Flow Switch - Building M
28	Wet-Flow Switch - Building N
29	Hi/Low Air Switches - Building A
30	Sprinkler Tamper Switches - Building A
31	Sprinkler Tamper Switches - Building B
32	Sprinkler Tamper Switches - Building C
33	Sprinkler Tamper Switches - Building D
34	Sprinkler Tamper Switches - Building E
35	Sprinkler Tamper Switches - Building F
36	Sprinkler Tamper Switches - Building G
37	Sprinkler Tamper Switches - Building H
38	Sprinkler Tamper Switches - Building J
39	Sprinkler Tamper Switches - Building K
40	Sprinkler Tamper Switches - Building L
41	Sprinkler Tamper Switches - Building M
42	Sprinkler Tamper Switches - Building N
43	Fire Alarm AC Power Failure - Building A
44	Fire Alarm System Low Battery - Building A
45	Open Circuit - Building A
46	Ground Fault - Building A
47	Notification Appliance Circuit Short - Building A
48	System Trouble - Building B
49	System Trouble - Building C
50	System Trouble - Building D
51	System Trouble - Building E
52	System Trouble - Building F
53	System Trouble - Building G
54	System Trouble - Building H
55	System Trouble - Building J
56	System Trouble - Building K
57	System Trouble - Building L
58	System Trouble - Building M
59	System Trouble - Building N
60	Full System Open Circuit
61	Full System Ground Fault

Activate Audible Alarm Signal For Building A
Activate Audible Alarm Signal For Building B
Activate Audible Alarm Signal For Building C
Activate Audible Alarm Signal For Building D
Activate Audible Alarm Signal For Building E
Activate Audible Alarm Signal For Building F
Activate Audible Alarm Signal For Building G
Activate Audible Alarm Signal For Building H
Activate Audible Alarm Signal For Building J
Activate Audible Alarm Signal For Building K
Activate Audible Alarm Signal For Building L
Activate Audible Alarm Signal For Building M
Activate Audible Sup Signal At Each Individual Bldg
Transmit Fire Alarm Signal to Supervising Station
Transmit Supervisory Signal to Supervising Station
Transmit Trouble Signal to Supervising Station
Indicated Status on the FACP

[illegible]

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

SYMBOL LEGEND	
	SMOKE DETECTOR
	HEAT DETECTOR
	HEAT DETECTOR *ATTIC*
	PULL-STATION
	WATER-FLOW
	TAMPER
	FACP
	WIRELESS COMM

FIRE ALARM ZONES

ZN-1	FACP SMOKE
ZN-2	BLDG A DRY FLOW
ZN-3	BLDG A LOW AIR
ZN-4	BLDG A DRY TAMPER
ZN-5	BLDG A PIV
ZN-6	BLDG A VAULT TAMP
ZN-7	BLDG A APARTMENT
ZN-8	BLDG A CLUB HOUSE