



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 12, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20230881

Property Address: 707 39TH AVE SE, Unit: D, PUYALLUP, WA 98374;

Contractor: Anthony Mizin 315 fifth Ave S. Suite 600 Seattle, WA 98104 WALSH CONSTRUCTION CO. 315 FIFTH AVE S, SUITE 600 SEATTLE, WA 98104- (206) 547-4008

To construct: As part of the Phase 2 development of Wesley Bradley Park, - Group R2 w/ 3 stories Type VA over Type 1A concrete garage. This project has 67 dwelling units. - WESLEY HOMES BRADLEY PARK PH 2 - BROWNSTONE

On this day we have inspected your construction for **Storm Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: -Inspected sewer connection to existing stub on north end of the Brownstone BLDG and elevation change to come up to BLDG exit elevation. Contractor still needs to install it to the BLDG. Will call in another inspection when work is complete.

Corrections:

Sincerely,

Michael Rosenau
Development Engineering Inspector
MRosenau@PuyallupWA.gov
(253) 344-6753