



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRGR20250189

March 18, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Engineering Civil Review	Jamie Carter	(253)435-3616	JCarter@puyallupwa.gov
<ul style="list-style-type: none"> - Standard eco blocks are two feet tall. Clarify the height of this wall or provide specs from manufacturer of custom eco blocks. - Double check all recorded documents associated with the affected parcels. In some areas the easement along the southern property line is suspected to be 24 feet wide. Provide private easement documentation to verify dimensions of burdened areas. - C2.0 shows this entire area gone. Clarify the extents of pave demo. - Bond required for Clear, Fill and Grade work. Provide on city documentation. The amount of the bond shall not be less than the total estimated construction cost of the interim and permanent erosion and sediment control measures per the approved cost estimate received prior to plan approval. Specifically, fill out the EROSION CONTROL line under ON Site Storm Drainage. See https://www.cityofpuyallup.org/DocumentCenter/View/16621/CFG-Bond-101822-appvd-by-Legal for more information. - Incorporate PMC 21.14.120 (2). This project is immediately adjacent to residential properties and some off site information is required. - For planning purposes: Attention to CoP Municipal Code 20.30.045(3)(c) 'Improvement and Maintenance of Outdoor Storage Areas. All outdoor storage areas and access to them shall be paved or otherwise surfaced and maintained so as to eliminate dust and mud. All outdoor storage areas shall be graded and stormwater facilities installed to collect and dispose of all surface runoff in accordance with City requirements'. Also standard buffers shall be applied to property lines. Consider these regulations when planning for the future acces road and storage areas in the context of berm location. 			
Planning Review	Chris Beale	(253)841-5418	CBeale@PuyallupWA.gov
<ul style="list-style-type: none"> - Project exceed 500 CY of grading and fill. Please submit a SEPA checklist with plans. Planning staff will provide project specific comments at the time of SEPA. 			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
Prior to Issuance	Please contact the DPS Support Specialist, Robin Loewen at RLOEWEN@PUYALLUPWA.GOV to request a pre-construction meeting prior to starting site work.	Engineering Division	Open
Prior to Issuance	A Performance Bond must be received by the City of Puyallup prior to permit issuance. The Performance Bond shall be 150% of the estimated cost of work in the ROW per the approved cost estimate received prior to plan approval (attached in CityView Portal under Documents & Images section). See https://www.cityofpuyallup.org/DocumentCenter/View/16622/Performance-Bond-51122-appvd-by-Legal for more information.	Engineering Division	Open
Prior to Issuance	Email a signed Inadvertent Discovery Plan to RLOEWEN@PUYALLUPWA.GOV.	Engineering Division	Open
Prior to Issuance	Overtime Inspection Fees / Main Shutdown Fees form is to be received prior to permit issuance. Signing this form is acknowledgement that there may be billed overtime inspection fees per the current fee schedule and that whenever the City Water Division staff is required to perform a mainline shutdown the fees shall be billed at \$134.00 per event plus \$10.00 per tag. Instances when a shutdown is performed outside regular working hour's additional overtime fees will be billed at the current overtime billing rate (3 hour minimum call out time).	Engineering Division	Open
Prior to Issuance	Certificate of Insurance/CG2012 must be received prior to issuance	Engineering Division	Open
Prior to Issuance	A Clear, Fill and, Grade Bond must be received by the City of Puyallup prior to permit issuance. The amount of the bond shall not be less than the total estimated construction cost of the interim and permanent erosion and sediment control measures per the approved cost estimate received prior to plan approval. See https://www.cityofpuyallup.org/DocumentCenter/View/16621/CFG-Bond-101822-appvd-by-Legal for more information.	Engineering Division	Open

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov