



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 18, 2025

Inspection Result: NOT READY

Permit Number: PRCNC20241019

Property Address: 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

Contractor: MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA 98409

To construct: Construct Early Learning Center

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete vapor barrier at slab at grid line - (1-7,A-J)
 - 2 ; complete rebar ar interior footings.
- not ready

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684