



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 24, 2025                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRMU20240404

**Property Address:** 2902 E PIONEER, BUILDING G, PUYALLUP, WA

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902  
E PIONEER - APT BLDG G \* REVISION (1) - 1/30/2025 - ENGINEERED  
TRUSS DRAWINGS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 complete putty packs at electrical boxes at tub/shower wall.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684