


Project Information East Town Crossing Unit 101 Building F Pioneer & Shaw, Puyallup	City of Puyallup Building REVIEWED FOR COMPLIANCE benowden 03/03/2025 10:36:52 AM 	Messages / Results * UA Reduction = 2.41, Proposed UA is better than baseline by 1% Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed * Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.	City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic
Contact Information Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117			

ANALYSIS SET UP

What code compliance pathway are you using? Project Building Type? Occupancy Type? Code Version? Classification: Baseline Description: About Your Selection:	Prescriptive Path Compliance with Option 1 (preferred) New Construction R2 Multifamily WSEC 2018 Small Dwelling Unit -- 819 sq. ft. Code Baseline - Baseline and proposed window areas are equal. Up to 15 sf exempt window and 24 sf exempt door allowable
--	---

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	104	31.1	0.300	104	31.1	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,203	67.4	0.054	1,203	65.0	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	133	72.0	0.540	133	72.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			182.4	Proposed UA Total			180.0
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.3%
				UA Reduction			2.4

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits

System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits

Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*
1	Efficient Building Envelope		0.0	
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.
4	High Efficiency HVAC Distribution System		NA	
5.1	Efficient Water Heating		0.0	
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater
6	Renewable Electric Energy		0.0	
7	Appliance Package		0.0	
Energy Credits			6.0	

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	R10 2' vertical (Code Baseline)	10-2	0.540		133	72
Sum of Perimeter and FP					133	72

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	55 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design		819 ft2
Conditioned Volume		6,962 ft3
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window		180
Envelope Heat Load		9,181 Btu / Hour
Sum of UA X ΔT		
Air Leakage Heat Load		3,834 Btu / Hour
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load		13,015 Btu / Hour
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load		13,015 Btu / Hour
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output		16,269 Btu / Hour
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 102 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.27, Proposed UA is better than baseline by 1%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 779 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	108	32.3	0.300	108	32.3	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,135	63.6	0.054	1,135	61.3	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	127	68.6	0.540	127	68.6	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			176.4	Proposed UA Total			174.1
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.3%
				UA Reduction			2.3

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)							
Plan ID	Component Description	Ref.	Floor U		Area	UA	
Sum of Area and UA					0	0	

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	R10 2' vertical (Code Baseline)	10-2	0.540		127	69
Sum of Perimeter and FP					127	69

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	55 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	779 ft ²	
Conditioned Volume	6,622 ft ³	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	174	
Envelope Heat Load	8,881 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	3,647 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	12,528 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	12,528 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	15,660 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 103 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.22, Proposed UA is better than baseline by 1%
Whole House Mechanical Ventilation Airflow Rate: 45 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 683 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	44	13.2	0.300	44	13.2	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,108	62.0	0.054	1,108	59.8	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	118	63.7	0.540	118	63.7	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			151.0	Proposed UA Total			148.7
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.5%
				UA Reduction			2.2

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)							
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP	
	R10 2' vertical (Code Baseline)	10-2	0.540		118	64	
Sum of Perimeter and FP					118	64	

Below Grade Walls and Slabs									
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA	
Sum of Area, Length and UA				0	0.0		0	0	

Ventilation Requirements				
Number of Bedrooms	1			
Run-Time Percent in Each 4-Hour Segment	100%			
Is the system Balanced?	Balanced			Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed			Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403			
Whole House Mechanical Ventilation Airflow Rate	45 CFM			

HVAC Thermal Distribution System			Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	683 ft2	
Conditioned Volume	5,806 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	149	
Envelope Heat Load	7,586 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	3,198 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	10,783 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	10,783 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	13,479 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 104 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.32, Proposed UA is better than baseline by 1%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 761 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	55	16.5	0.300	55	16.5	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,162	65.1	0.054	1,162	62.8	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	125	67.2	0.540	125	67.2	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			160.8	Proposed UA Total			158.5
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.4%
				UA Reduction			2.3

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule										Rows to Show	2
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
					Feet	Inch	Feet	Inch			
Exempt			-						-	-	
1 3	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	6	6	0	15.0	4.50	
2 7	U=0.30 (Code Baseline)	Table 406.2	0.30	2	5	0	4	0	40.0	12.00	
Sum of Area and UA									55.0	16.5	
Vertical Glazing Area Weighted U										0.300	
Vertical Glazing and Doors Area Weighted U										0.300	

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,162	63
Sum of Area and UA					1,162	63

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	R10 2' vertical (Code Baseline)	10-2	0.540		125	67
Sum of Perimeter and FP					125	67

Below Grade Walls and Slabs									
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA	
Sum of Area, Length and UA				0	0.0		0	0	

Ventilation Requirements				
Number of Bedrooms	2			
Run-Time Percent in Each 4-Hour Segment	100%			
Is the system Balanced?	Balanced			Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed			Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403			
Whole House Mechanical Ventilation Airflow Rate	55 CFM			

HVAC Thermal Distribution System			Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	761 ft2	
Conditioned Volume	6,469 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	159	
Envelope Heat Load	8,084 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	3,563 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	11,646 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	11,646 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	14,558 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 105 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.61, Proposed UA is better than baseline by 1%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1055 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	78	23.4	0.300	78	23.4	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,303	72.9	0.054	1,303	70.3	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	141	76.0	0.540	141	76.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			184.3	Proposed UA Total		181.7	
Required Credits			4.5	Proposed Credits		7.0	from Tables 406.2 and 406.3
				UA Percent Reduction		1.4%	
				UA Reduction		2.6	

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits

System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits

Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*
1	Efficient Building Envelope		0.0	
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.
4	High Efficiency HVAC Distribution System		NA	
5.1	Efficient Water Heating		0.0	
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater
6	Renewable Electric Energy		0.0	
7	Appliance Package		0.0	
Energy Credits			6.0	

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)							
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP	
	R10 2' vertical (Code Baseline)	10-2	0.540		141	76	
Sum of Perimeter and FP					141	76	

Below Grade Walls and Slabs									
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA	
Sum of Area, Length and UA				0	0.0		0	0	

Ventilation Requirements				
Number of Bedrooms	2			
Run-Time Percent in Each 4-Hour Segment	100%			
Is the system Balanced?	Balanced			Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed			Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403			
Whole House Mechanical Ventilation Airflow Rate	70 CFM			

HVAC Thermal Distribution System			Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	1,055 ft2	
Conditioned Volume	8,968 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	182	
Envelope Heat Load	9,267 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	4,939 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	14,206 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	14,206 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	17,758 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 106 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 0.05, Proposed UA is better than baseline by 0%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1005 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	70	20.9	0.300	70	20.9	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	27	1.5	0.054	27	1.5	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	147	79.3	0.540	147	79.3	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			113.7	Proposed UA Total			113.7
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			0.0%
				UA Reduction			0.1

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule										Rows to Show	3
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
					Feet	Inch	Feet	Inch			
Exempt			-						-	-	
1	5	U=0.30 (Code Baseline)	Table 406.2	0.30	1	4	6	3	6	15.8	4.73
2	8	U=0.30 (Code Baseline)	Table 406.2	0.30	1	5	0	6	0	30.0	9.00
3	10	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	4	0	24.0	7.20
Sum of Area and UA										69.8	20.9
Vertical Glazing Area Weighted U											0.300
Vertical Glazing and Doors Area Weighted U											0.300

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		27	1
Sum of Area and UA					27	1

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	R10 2' vertical (Code Baseline)	10-2	0.540		147	79
Sum of Perimeter and FP					147	79

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources	Link
Compliance Certificate	Compliance Certificate Instructions
Insulation Certificate for Residential New Construction	Insulation Certificate
Duct Testing Affidavits	
	Existing Construction Affidavit, Existing
	New Construction Affidavit, New
Prescriptive Checklist for 2018 WSEC	Prescriptive Checklist
Alterations (Remodel) Worksheet	Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	1,005 ft ²	
Conditioned Volume	8,543 ft ³	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	114	
Envelope Heat Load	5,796 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	4,705 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	10,501 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	10,501 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	13,127 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 107 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.65, Proposed UA is better than baseline by 1%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1149 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	130	38.9	0.300	130	38.9	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,327	74.3	0.054	1,327	71.7	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	148	80.0	0.540	148	80.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			205.2	Proposed UA Total			202.6
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.3%
				UA Reduction			2.7

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)							
Plan ID	Component Description	Ref.	Floor U		Area	UA	
Sum of Area and UA					0	0	

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	R10 2' vertical (Code Baseline)	10-2	0.540		148	80
Sum of Perimeter and FP					148	80

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	3
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design		1,149 ft ²
Conditioned Volume		9,767 ft ³
	Leave blank to use default of 8.5 ft. ceiling height	
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window		203
Envelope Heat Load		10,330 Btu / Hour
	Sum of UA X ΔT	
Air Leakage Heat Load		5,379 Btu / Hour
	((Volume X 0.6) X ΔT) X .018))	
Building Design Heat Load		15,710 Btu / Hour
	Air Leakage + Envelope Heat Loss	
Building and Duct Heat Load		15,710 Btu / Hour
	For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1	
	For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1	
Maximum Heat Equipment Output		19,637 Btu / Hour
	Building and Duct Heat Loss X 1.25 for heat pumps	
	Building and Duct Heat Loss X 1.40 for all other systems	

Project Information
East Town Crossing Unit 108 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.79, Proposed UA is better than baseline by 0%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1075 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	101	30.4	0.300	101	30.4	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,397	78.2	0.054	1,397	75.5	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	1,075	580.5	0.540	1,075	580.5	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			701.1	Proposed UA Total			698.3
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			0.4%
				UA Reduction			2.8

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule									Rows to Show	3	
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
					Feet	Inch	Feet	Inch			
Exempt			-						-	-	
1	5	U=0.30 (Code Baseline)	Table 406.2	0.30	3	4	6	3	6	47.3	14.18
2	8	U=0.30 (Code Baseline)	Table 406.2	0.30	1	5	0	6	0	30.0	9.00
3	10	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	4	0	24.0	7.20
Sum of Area and UA									101.3	30.4	
Vertical Glazing Area Weighted U										0.300	
Vertical Glazing and Doors Area Weighted U										0.300	

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,397	75
Sum of Area and UA					1,397	75

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	R10 2' vertical (Code Baseline)	10-2	0.540		1,075	581
Sum of Perimeter and FP					1,075	581

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	3
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018)	http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design	1,075 ft2	
Conditioned Volume	9,138 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window	698	
Envelope Heat Load	35,615 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	5,033 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	40,648 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	40,648 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	50,810 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 201 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.43, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 819 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	92	27.5	0.300	92	27.5	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,215	68.0	0.054	1,215	65.6	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			107.5	Proposed UA Total		105.1	
Required Credits			4.5	Proposed Credits		7.0	from Tables 406.2 and 406.3
				UA Percent Reduction		2.3%	
				UA Reduction		2.4	

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule										Rows to Show		3
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA		
					Feet	Inch	Feet	Inch				
Exempt			-						-	-		
1 2	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	6	3	0	7.5	2.25		
2 7	U=0.30 (Code Baseline)	Table 406.2	0.30	3	5	0	4	0	60.0	18.00		
3 11	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	4	0	24.0	7.20		
Sum of Area and UA									91.5	27.5		
Vertical Glazing Area Weighted U										0.300		
Vertical Glazing and Doors Area Weighted U										0.300		

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,215	66
Sum of Area and UA					1,215	66

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	55 CFM

HVAC Thermal Distribution System		Download RS-33 (2018)	http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design		819 ft2
Conditioned Volume		6,962 ft3
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window		105
Envelope Heat Load		5,358 Btu / Hour
Sum of UA X ΔT		
Air Leakage Heat Load		3,834 Btu / Hour
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load		9,193 Btu / Hour
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load		9,193 Btu / Hour
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output		11,491 Btu / Hour
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 202 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.25, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 779 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	116	34.7	0.300	116	34.7	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,127	63.1	0.054	1,127	60.9	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			109.8	Proposed UA Total			107.5
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			2.1%
				UA Reduction			2.3

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule									Rows to Show	3	
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
Exempt					Feet	Inch	Feet	Inch			
			-						-	-	
1	2	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	6	3	0	7.5	2.25
2	9	U=0.30 (Code Baseline)	Table 406.2	0.30	3	6	0	4	0	72.0	21.60
3	11	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	6	0	36.0	10.80
Sum of Area and UA									115.5	34.7	
Vertical Glazing Area Weighted U										0.300	
Vertical Glazing and Doors Area Weighted U										0.300	

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,127	61
Sum of Area and UA					1,127	61

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	55 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources	Link
Compliance Certificate	Compliance Certificate Instructions
Insulation Certificate for Residential New Construction	Insulation Certificate
Duct Testing Affidavits	
	Existing Construction Affidavit, Existing
	New Construction Affidavit, New
Prescriptive Checklist for 2018 WSEC	Prescriptive Checklist
Alterations (Remodel) Worksheet	Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	779 ft2	
Conditioned Volume	6,622 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	108	
Envelope Heat Load	5,483 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	3,647 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	9,131 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	9,131 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	11,413 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 203 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.21, Proposed UA is better than baseline by 3%
Whole House Mechanical Ventilation Airflow Rate: 45 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 682 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	47	14.1	0.300	47	14.1	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,105	61.9	0.054	1,105	59.7	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			88.0	Proposed UA Total			85.8
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			2.5%
				UA Reduction			2.2

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements			
Number of Bedrooms	1		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced	Verify system meets definition of 'Balanced Whole-House Ventilation'	
Is the system Distributed?	Distributed	Verify system meets definition of 'Distributed Whole-House Ventilation'	
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	45 CFM		

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	682 ft2	
Conditioned Volume	5,797 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	86	
Envelope Heat Load	4,374 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	3,193 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	7,567 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	7,567 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	9,458 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 204 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.39, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 780 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	63	18.9	0.300	63	18.9	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,195	66.9	0.054	1,195	64.5	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			97.8	Proposed UA Total		95.4	
Required Credits			4.5	Proposed Credits		7.0	from Tables 406.2 and 406.3
				UA Percent Reduction		2.4%	
				UA Reduction		2.4	

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule										Rows to Show	2	
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA		
					Feet	Inch	Feet	Inch				
Exempt			-						-	-		
13	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	6	6	0	15.0	4.50		
29	U=0.30 (Code Baseline)	Table 406.2	0.30	2	6	0	4	0	48.0	14.40		
Sum of Area and UA									63.0	18.9		
Vertical Glazing Area Weighted U									0.300			
Vertical Glazing and Doors Area Weighted U									0.300			

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,195	65
Sum of Area and UA					1,195	65

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements			
Number of Bedrooms	2		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced		Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed		Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	55 CFM		

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20	
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool	
Nearest Weather Station	Puyallup		
Indoor Design Temperature	70 F		
Outdoor Design Temperature	19 F		
Design Temperature Difference (ΔT)	51 F		
Conditioned Floor Area, Proposed Design	780 ft2		
Conditioned Volume	6,630 ft3		
Leave blank to use default of 8.5 ft. ceiling height			
HVAC System Type	Heat Pump		
Location of HVAC Distribution System	Unducted		
Sum of UA, including exempt door and window	95		
Envelope Heat Load	4,867 Btu / Hour		
Sum of UA X ΔT			
Air Leakage Heat Load	3,652 Btu / Hour		
((Volume X 0.6) X ΔT) X .018))			
Building Design Heat Load	8,518 Btu / Hour		
Air Leakage + Envelope Heat Loss			
Building and Duct Heat Load	8,518 Btu / Hour		
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1			
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1			
Maximum Heat Equipment Output	10,648 Btu / Hour		
Building and Duct Heat Loss X 1.25 for heat pumps			
Building and Duct Heat Loss X 1.40 for all other systems			

Project Information
East Town Crossing Unit 205 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.61, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1055 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	78	23.4	0.300	78	23.4	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,303	73.0	0.054	1,303	70.4	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			108.4	Proposed UA Total			105.8
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			2.4%
				UA Reduction			2.6

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule										Rows to Show	2
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
					Feet	Inch	Feet	Inch			
Exempt			-						-	-	
18	U=0.30 (Code Baseline)	Table 406.2	0.30	1	5	0	6	0	30.0	9.00	
210	U=0.30 (Code Baseline)	Table 406.2	0.30	2	6	0	4	0	48.0	14.40	
Sum of Area and UA									78.0	23.4	
Vertical Glazing Area Weighted U									0.300		
Vertical Glazing and Doors Area Weighted U									0.300		

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,303	70
Sum of Area and UA					1,303	70

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements			
Number of Bedrooms	2		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced		Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed		Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	70 CFM		

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20	
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool	
Nearest Weather Station	Puyallup		
Indoor Design Temperature	70 F		
Outdoor Design Temperature	19 F		
Design Temperature Difference (ΔT)	51 F		
Conditioned Floor Area, Proposed Design	1,055 ft ²		
Conditioned Volume	8,968 ft ³		
Leave blank to use default of 8.5 ft. ceiling height			
HVAC System Type	Heat Pump		
Location of HVAC Distribution System	Unducted		
Sum of UA, including exempt door and window	106		
Envelope Heat Load	5,394 Btu / Hour		
Sum of UA X ΔT			
Air Leakage Heat Load	4,939 Btu / Hour		
((Volume X 0.6) X ΔT) X .018))			
Building Design Heat Load	10,333 Btu / Hour		
Air Leakage + Envelope Heat Loss			
Building and Duct Heat Load	10,333 Btu / Hour		
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1			
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1			
Maximum Heat Equipment Output	12,917 Btu / Hour		
Building and Duct Heat Loss X 1.25 for heat pumps			
Building and Duct Heat Loss X 1.40 for all other systems			

Project Information
East Town Crossing Unit 206 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.75, Proposed UA is better than baseline by 3%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1005 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	70	20.9	0.300	70	20.9	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,373	76.9	0.054	1,373	74.1	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			109.8	Proposed UA Total			107.1
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			2.5%
				UA Reduction			2.7

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources	Link
Compliance Certificate	Compliance Certificate Instructions
Insulation Certificate for Residential New Construction	Insulation Certificate
Duct Testing Affidavits	
	Existing Construction Affidavit, Existing
	New Construction Affidavit, New
Prescriptive Checklist for 2018 WSEC	Prescriptive Checklist
Alterations (Remodel) Worksheet	Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	1,005 ft ²	
Conditioned Volume	8,543 ft ³	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	107	
Envelope Heat Load	5,460 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	4,705 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	10,165 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	10,165 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	12,707 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 207 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.65, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1149 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	130	38.9	0.300	130	38.9	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,327	74.3	0.054	1,327	71.7	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			125.2	Proposed UA Total		122.5	
Required Credits			4.5	Proposed Credits		7.0	from Tables 406.2 and 406.3
				UA Percent Reduction		2.1%	
				UA Reduction		2.7	

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits

System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits

Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*
1	Efficient Building Envelope		0.0	
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.
4	High Efficiency HVAC Distribution System		NA	
5.1	Efficient Water Heating		0.0	
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater
6	Renewable Electric Energy		0.0	
7	Appliance Package		0.0	
Energy Credits			6.0	

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule									Rows to Show	4	
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
Exempt					Feet	Inch	Feet	Inch			
			-						-	-	
1	2	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	6	3	0	7.5	2.25
2	10	U=0.30 (Code Baseline)	Table 406.2	0.30	3	6	0	4	0	72.0	21.60
3	11	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	6	0	36.0	10.80
4	12	U=0.30 (Code Baseline)	Table 406.2	0.30	1	7	0	2	0	14.0	4.20
Sum of Area and UA									129.5	38.9	
Vertical Glazing Area Weighted U										0.300	
Vertical Glazing and Doors Area Weighted U										0.300	

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,327	72
Sum of Area and UA					1,327	72

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	3
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

Verify system meets definition of 'Balanced Whole-House Ventilation'

Verify system meets definition of 'Distributed Whole-House Ventilation'

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design		1,149 ft ²
Conditioned Volume		9,767 ft ³
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window		123
Envelope Heat Load		6,249 Btu / Hour
Sum of UA X ΔT		
Air Leakage Heat Load		5,379 Btu / Hour
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load		11,628 Btu / Hour
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load		11,628 Btu / Hour
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output		14,535 Btu / Hour
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 208 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.79, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1075 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	101	30.4	0.300	101	30.4	
Flat/Vaulted Ceilings U =	0.027	0	0.0		0	0.0	
Wall (above grade) U =	0.056	1,397	78.2	0.054	1,397	75.5	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			120.6	Proposed UA Total			117.8
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			2.3%
				UA Reduction			2.8

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule									Rows to Show	3	
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
					Feet	Inch	Feet	Inch			
Exempt			-						-	-	
1	5	U=0.30 (Code Baseline)	Table 406.2	0.30	3	4	6	3	6	47.3	14.18
2	8	U=0.30 (Code Baseline)	Table 406.2	0.30	1	5	0	6	0	30.0	9.00
3	10	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	4	0	24.0	7.20
Sum of Area and UA									101.3	30.4	
Vertical Glazing Area Weighted U										0.300	
Vertical Glazing and Doors Area Weighted U										0.300	

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	No ceiling/roof in thermal envelope	NA	-			0.0
Sum of Area and UA					0	0.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,397	75
Sum of Area and UA					1,397	75

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	3
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources	Link
Compliance Certificate	Compliance Certificate Instructions
Insulation Certificate for Residential New Construction	Insulation Certificate
Duct Testing Affidavits	
	Existing Construction Affidavit, Existing
	New Construction Affidavit, New
Prescriptive Checklist for 2018 WSEC	Prescriptive Checklist
Alterations (Remodel) Worksheet	Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	1,075 ft ²	
Conditioned Volume	9,138 ft ³	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	118	
Envelope Heat Load	6,009 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	5,033 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	11,042 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	11,042 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	13,803 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 301 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.43, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 819 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	92	27.5	0.300	92	27.5	
Flat/Vaulted Ceilings U =	0.027	819	22.1	0.027	819	22.1	
Wall (above grade) U =	0.056	1,215	68.0	0.054	1,215	65.6	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			129.6	Proposed UA Total			127.2
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.9%
				UA Reduction			2.4

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		819	22.1
Sum of Area and UA					819	22.1

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	55 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design		819 ft2
Conditioned Volume		6,962 ft3
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window		127
Envelope Heat Load		6,486 Btu / Hour
Sum of UA X ΔT		
Air Leakage Heat Load		3,834 Btu / Hour
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load		10,321 Btu / Hour
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load		10,321 Btu / Hour
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output		12,901 Btu / Hour
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 302 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.25, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 779 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	114	34.2	0.300	114	34.2	
Flat/Vaulted Ceilings U =	0.027	779	21.0	0.027	779	21.0	
Wall (above grade) U =	0.056	1,127	63.1	0.054	1,127	60.8	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			130.3	Proposed UA Total			128.1
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.7%
				UA Reduction			2.3

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Exterior Doors										
Plan	Component		Door		Width		Height		Area	UA
ID	Description	Ref.	U	Qt.	Feet	Inch	Feet	Inch		
Exempt									0	0.0
302A	Code Baseline, U=0.30	-	0.30	1	3	0	6	8	20	6.0
302B	Code Baseline, U=0.30	-	0.30	1	3	0	6	8	20	6.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
									0	0.0
Sum of Area and UA									40	12.0
Exterior Doors Area Weighted U										0.300

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule									Rows to Show	3
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
Exempt			-						-	-
1	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	0	3	0	6.0	1.80
2	U=0.30 (Code Baseline)	Table 406.2	0.30	3	6	0	4	0	72.0	21.60
3	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	6	0	36.0	10.80
Sum of Area and UA									114.0	34.2
Vertical Glazing Area Weighted U										0.300
Vertical Glazing and Doors Area Weighted U										0.300

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		779	21.0
Sum of Area and UA					779	21.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,127	61
Sum of Area and UA					1,127	61

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	55 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design		779 ft2
Conditioned Volume		6,622 ft3
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window		128
Envelope Heat Load		6,532 Btu / Hour
Sum of UA X ΔT		
Air Leakage Heat Load		3,647 Btu / Hour
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load		10,179 Btu / Hour
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load		10,179 Btu / Hour
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output		12,724 Btu / Hour
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 303 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 0.05, Proposed UA is better than baseline by 0%
Whole House Mechanical Ventilation Airflow Rate: 45 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 683 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	44	13.2	0.300	44	13.2	
Flat/Vaulted Ceilings U =	0.027	683	18.4	0.027	683	18.4	
Wall (above grade) U =	0.056	24	1.3	0.054	24	1.3	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			45.0	Proposed UA Total			44.9
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			0.1%
				UA Reduction			0.0

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		683	18.4
Sum of Area and UA					683	18.4

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements			
Number of Bedrooms	1		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced		Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed		Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	45 CFM		

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20	
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool	
Nearest Weather Station	Puyallup		
Indoor Design Temperature	70 F		
Outdoor Design Temperature	19 F		
Design Temperature Difference (ΔT)	51 F		
Conditioned Floor Area, Proposed Design	683 ft2		
Conditioned Volume	5,806 ft3		
Leave blank to use default of 8.5 ft. ceiling height			
HVAC System Type	Heat Pump		
Location of HVAC Distribution System	Unducted		
Sum of UA, including exempt door and window	45		
Envelope Heat Load	2,292 Btu / Hour		
Sum of UA X ΔT			
Air Leakage Heat Load	3,198 Btu / Hour		
((Volume X 0.6) X ΔT) X .018))			
Building Design Heat Load	5,489 Btu / Hour		
Air Leakage + Envelope Heat Loss			
Building and Duct Heat Load	5,489 Btu / Hour		
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1			
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1			
Maximum Heat Equipment Output	6,861 Btu / Hour		
Building and Duct Heat Loss X 1.25 for heat pumps			
Building and Duct Heat Loss X 1.40 for all other systems			

Project Information
East Town Crossing Unit 304 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.39, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 55 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 780 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	63	18.9	0.300	63	18.9	
Flat/Vaulted Ceilings U =	0.027	780	21.1	0.027	780	21.1	
Wall (above grade) U =	0.056	1,195	66.9	0.054	1,195	64.5	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			118.9	Proposed UA Total			116.5
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			2.0%
				UA Reduction			2.4

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		780	21.1
Sum of Area and UA					780	21.1

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements			
Number of Bedrooms	2		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced	Verify system meets definition of 'Balanced Whole-House Ventilation'	
Is the system Distributed?	Distributed	Verify system meets definition of 'Distributed Whole-House Ventilation'	
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	55 CFM		

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	780 ft2	
Conditioned Volume	6,630 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	116	
Envelope Heat Load	5,941 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	3,652 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	9,592 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	9,592 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	11,990 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 305 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.61, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1055 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	78	23.4	0.300	78	23.4	
Flat/Vaulted Ceilings U =	0.027	1,055	28.5	0.027	1,055	28.5	
Wall (above grade) U =	0.056	1,303	73.0	0.054	1,303	70.4	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			136.9	Proposed UA Total			134.3
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.9%
				UA Reduction			2.6

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		1,055	28.5
Sum of Area and UA					1,055	28.5

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements			
Number of Bedrooms	2		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced		Verify system meets definition of 'Balanced Whole-House Ventilation'
Is the system Distributed?	Distributed		Verify system meets definition of 'Distributed Whole-House Ventilation'
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	70 CFM		

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20	
Is this a hydronic heating system?	No		
Location of Ducts	Unducted		
Location of Air Handler	Unconditioned Space		
Is Duct Testing Required? No			

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool	
Nearest Weather Station	Puyallup		
Indoor Design Temperature	70 F		
Outdoor Design Temperature	19 F		
Design Temperature Difference (ΔT)	51 F		
Conditioned Floor Area, Proposed Design	1,055 ft2		
Conditioned Volume	8,968 ft3		
Leave blank to use default of 8.5 ft. ceiling height			
HVAC System Type	Heat Pump		
Location of HVAC Distribution System	Unducted		
Sum of UA, including exempt door and window	134		
Envelope Heat Load	6,847 Btu / Hour		
Sum of UA X ΔT			
Air Leakage Heat Load	4,939 Btu / Hour		
((Volume X 0.6) X ΔT) X .018))			
Building Design Heat Load	11,786 Btu / Hour		
Air Leakage + Envelope Heat Loss			
Building and Duct Heat Load	11,786 Btu / Hour		
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1			
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1			
Maximum Heat Equipment Output	14,733 Btu / Hour		
Building and Duct Heat Loss X 1.25 for heat pumps			
Building and Duct Heat Loss X 1.40 for all other systems			

Project Information
East Town Crossing Unit 306 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.75, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed
<small>* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.</small>

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1005 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	70	20.9	0.300	70	20.9	
Flat/Vaulted Ceilings U =	0.027	1,005	27.1	0.027	1,005	27.1	
Wall (above grade) U =	0.056	1,373	76.9	0.054	1,373	74.1	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			136.9	Proposed UA Total		134.2	
Required Credits			4.5	Proposed Credits		7.0	from Tables 406.2 and 406.3
				UA Percent Reduction		2.0%	
				UA Reduction		2.7	

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule										Rows to Show	3
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
					Feet	Inch	Feet	Inch			
Exempt			-						-	-	
1	5	U=0.30 (Code Baseline)	Table 406.2	0.30	1	4	6	3	6	15.8	4.73
2	8	U=0.30 (Code Baseline)	Table 406.2	0.30	1	5	0	6	0	30.0	9.00
3	10	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	4	0	24.0	7.20
Sum of Area and UA										69.8	20.9
Vertical Glazing Area Weighted U											0.300
Vertical Glazing and Doors Area Weighted U											0.300

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		1,005	27.1
Sum of Area and UA					1,005	27.1

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,373	74
Sum of Area and UA					1,373	74

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	2
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources	Link
Compliance Certificate	Compliance Certificate Instructions
Insulation Certificate for Residential New Construction	Insulation Certificate
Duct Testing Affidavits	
	Existing Construction Affidavit, Existing
	New Construction Affidavit, New
Prescriptive Checklist for 2018 WSEC	Prescriptive Checklist
Alterations (Remodel) Worksheet	Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	1,005 ft ²	
Conditioned Volume	8,543 ft ³	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	134	
Envelope Heat Load	6,844 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	4,705 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	11,549 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	11,549 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	14,437 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 307 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.66, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1149 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	130	38.9	0.300	130	38.9	
Flat/Vaulted Ceilings U =	0.027	1,149	31.0	0.027	1,149	31.0	
Wall (above grade) U =	0.056	1,328	74.4	0.054	1,328	71.7	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			156.3	Proposed UA Total			153.6
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.7%
				UA Reduction			2.7

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

[illegible]

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Vertical Glazing Schedule									Rows to Show	4	
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA	
Exempt.					Feet	Inch	Feet	Inch			
			-						-	-	
1	2	U=0.30 (Code Baseline)	Table 406.2	0.30	1	2	6	3	0	7.5	2.25
2	10	U=0.30 (Code Baseline)	Table 406.2	0.30	3	6	0	4	0	72.0	21.60
3	11	U=0.30 (Code Baseline)	Table 406.2	0.30	1	6	0	6	0	36.0	10.80
4	12	U=0.30 (Code Baseline)	Table 406.2	0.30	1	7	0	2	0	14.0	4.20
Sum of Area and UA									129.5	38.9	
Vertical Glazing Area Weighted U										0.300	
Vertical Glazing and Doors Area Weighted U										0.300	

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		1,149	31.0
Sum of Area and UA					1,149	31.0

Walls (Above Grade)						
Plan ID	Component Description	Ref.	Wall U		Net Area	UA
	R21 cavity+R0 foam INT 2X6W Lap (Code Baseline)	10-5	0.054		1,328	72
Sum of Area and UA					1,328	72

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs									
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA	
Sum of Area, Length and UA				0	0.0		0	0	

Ventilation Requirements			
Number of Bedrooms	3		
Run-Time Percent in Each 4-Hour Segment	100%		
Is the system Balanced?	Balanced	Verify system meets definition of 'Balanced Whole-House Ventilation'	
Is the system Distributed?	Distributed	Verify system meets definition of 'Distributed Whole-House Ventilation'	
Ventilation Code Section	IMC, Section 403		
Whole House Mechanical Ventilation Airflow Rate	70	CFM	

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station	Puyallup	
Indoor Design Temperature	70 F	
Outdoor Design Temperature	19 F	
Design Temperature Difference (ΔT)	51 F	
Conditioned Floor Area, Proposed Design	1,149 ft ²	
Conditioned Volume	9,767 ft ³	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type	Heat Pump	
Location of HVAC Distribution System	Unducted	
Sum of UA, including exempt door and window	154	
Envelope Heat Load	7,834 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	5,379 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	13,213 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	13,213 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	16,516 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		

Project Information
East Town Crossing Unit 308 Building F Pioneer & Shaw, Puyallup
Contact Information
Synthesis 9, LLC Brett Lindsay blindsay@synthesis9.com 253-468-4117

Messages / Results *
UA Reduction = 2.79, Proposed UA is better than baseline by 2%
Whole House Mechanical Ventilation Airflow Rate: 70 CFM with Run Time Percent of 100%, Balanced, Distributed

* Results assume your inputs are complete and correct. Results do not constitute an approval. Analysis should be reviewed by your AHJ.

ANALYSIS SET UP

What code compliance pathway are you using?	Prescriptive Path Compliance with Option 1 (preferred)
Project Building Type?	New Construction
Occupancy Type?	R2 Multifamily
Code Version?	WSEC 2018
Classification:	Small Dwelling Unit -- 1075 sq. ft.
Baseline Description:	Code Baseline - Baseline and proposed window areas are equal.
About Your Selection:	Up to 15 sf exempt window and 24 sf exempt door allowable

RESULTS - Comparison of Baseline and Proposed Design

Component Performance, R occupancies				Proposed Design			
	U	Area	UA	U	Area	UA	
Doors U =	0.300	40	12.0	0.300	40	12.0	
Overhead Glazing U =	0.500	0	0.0		0	0.0	
Vertical Glazing U =	0.300	101	30.4	0.300	101	30.4	
Flat/Vaulted Ceilings U =	0.027	1,075	29.0	0.027	1,075	29.0	
Wall (above grade) U =	0.056	1,397	78.2	0.054	1,397	75.5	
Floors over Crawlspce U =	0.029	0	0.0		0	0.0	
Slab on Grade F =	0.540	0	0.0		0	0.0	
Below Grade Wall U =	0.042	0	0.0		0	0.0	
Below Grade Slab F =	0.570	0	0.0		0	0.0	
Baseline UA Total			149.6	Proposed UA Total			146.9
Required Credits			4.5	Proposed Credits			7.0
				UA Percent Reduction			1.9%
				UA Reduction			2.8

If the Proposed UA ≤ the Target UA, and the Proposed Credits from Table 406 are ≥ those required in Section R406, then the home meets the WSEC.

Table R406.2 Fuel Normalization Credits					
System No.	Full Description	Select System Type	Fuel Normalization Credits (406.2)	Energy Credits (406.3)	Total Credits (406.2 & 406.3)
2	For an initial heating system using a heat pump that meets federal standards for the equipment listed in Table C403.3.2(1)C or C403.3.2(2) OR Air to water heat pump units that are configured to provide both heating and cooling and are rated in accordance with AHRI 550/590. Heat pump with electric resistance or fossil-fuel supplemental heat requires compliance with WSEC 403.1.2 "Heat Pump Supplementary Heat". Packaged Terminal Heat Pumps (PTAC-HP) requires an HSPF tested value (See SBC Interpretation dated December 2020).	Heat Pump, air-to-air or air to water	1.0	6.0	7.0

Table R406.3 Energy Credits					
Option No.	Category	Select Options	Energy Credits	Brief Description of Selected Options*	
1	Efficient Building Envelope		0.0		
2	Air Leakage Control and Efficient Ventilation	Option 2.2	1.5	2.0 ACH50 / Heat Recovery Ventilation min eff 65% / For R2, 0.25 cfm per ft2 at 50 Pa / HRV with min SHR eff of 0.65	
3	High Efficiency HVAC	Option 3.4	2.0	Ductless Split System, Zonal Control. Min HSPF of 10.	
4	High Efficiency HVAC Distribution System		NA		
5.1	Efficient Water Heating		0.0		
5.2-5.6	Efficient Water Heating	Option 5.5	2.5	NEEA Tier 3 heat pump water heater	
6	Renewable Electric Energy		0.0		
7	Appliance Package		0.0		
Energy Credits			6.0		

*Refer to WSEC 2018 Table R406.3 for complete option descriptions and requirements

THERMAL ENVELOPE DETAILS - Proposed Design

Overhead Glazing										
Plan ID	Component Description	Ref.	Glazing U	Qt.	Width		Height		Area	UA
					Feet	Inch	Feet	Inch		
									0	
									0	
									0	
									0	
									0	
Sum of Area and UA									0	0
Overhead Glazing Area Weighted U										

Flat/Vaulted Ceilings						
Plan ID	Component Description	Ref.	Attic U		Area	UA
	R49 blown Attic STD baffled (Code Baseline, Option 1.1-1.4)	10-7	0.027		1,075	29.0
Sum of Area and UA					1,075	29.0

Floor (over crawl or exterior)						
Plan ID	Component Description	Ref.	Floor U		Area	UA
	No floors in thermal envelope	NA	-			0
Sum of Area and UA					0	0

Slab on Grade (less than 2 feet below grade)						
Plan ID	Component Description	Ref.	Slab F		Slab Perim	FP
	No slab on grade	NA	-			0
Sum of Perimeter and FP					0	0

Below Grade Walls and Slabs								
Plan ID	Component Description	Ref.	Wall U	Wall Area	Wall UA	Slab F	Slab Perim	Slab UA
Sum of Area, Length and UA				0	0.0		0	0

Ventilation Requirements	
Number of Bedrooms	3
Run-Time Percent in Each 4-Hour Segment	100%
Is the system Balanced?	Balanced
Is the system Distributed?	Distributed
Ventilation Code Section	IMC, Section 403
Whole House Mechanical Ventilation Airflow Rate	70 CFM

HVAC Thermal Distribution System		Download RS-33 (2018) http://www.energy.wsu.edu/Documents/Duct%20Testing%20Standards%20
Is this a hydronic heating system?	No	
Location of Ducts	Unducted	
Location of Air Handler	Unconditioned Space	
Is Duct Testing Required? No		

Links to Download Forms, Checklists and Other Resources		Link
Compliance Certificate		Compliance Certificate Instructions
Insulation Certificate for Residential New Construction		Insulation Certificate
Duct Testing Affidavits		
	Existing Construction	Affidavit, Existing
	New Construction	Affidavit, New
Prescriptive Checklist for 2018 WSEC		Prescriptive Checklist
Alterations (Remodel) Worksheet		Worksheet

Heating System Sizing - Proposed Design		Try Out BetterBuiltNW's HVAC Sizing Tool: https://betterbuiltnw.com/resources/hvac-sizing-tool
Nearest Weather Station		Puyallup
Indoor Design Temperature		70 F
Outdoor Design Temperature		19 F
Design Temperature Difference (ΔT)		51 F
Conditioned Floor Area, Proposed Design	1,075 ft2	
Conditioned Volume	9,138 ft3	
Leave blank to use default of 8.5 ft. ceiling height		
HVAC System Type		Heat Pump
Location of HVAC Distribution System		Unducted
Sum of UA, including exempt door and window	147	
Envelope Heat Load	7,490 Btu / Hour	
Sum of UA X ΔT		
Air Leakage Heat Load	5,033 Btu / Hour	
((Volume X 0.6) X ΔT) X .018))		
Building Design Heat Load	12,522 Btu / Hour	
Air Leakage + Envelope Heat Loss		
Building and Duct Heat Load	12,522 Btu / Hour	
For ducts located in unconditioned space: Sum of Building Heat Loss X 1.1		
For ducts located in conditioned space or ductless: Sum of Building Heat Loss X 1		
Maximum Heat Equipment Output	15,653 Btu / Hour	
Building and Duct Heat Loss X 1.25 for heat pumps		
Building and Duct Heat Loss X 1.40 for all other systems		