



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 27, 2025

Inspection Result: **FAILED**

Permit Number: PRMU20240139

Property Address: 2902 E PIONEER - BUILDING B, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - 2902 E PIONEER – APT BLDG B * REVISION (1) - 1/30/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Shear Wall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete all straps as per city approved plans.
- 2 ; provide special inspection approval of missing straps.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684