



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 01, 2025

Inspection Result: NOT READY

Permit Number: PRCTI20241698

Property Address: 3500 S MERIDIAN, Unit: 503, PUYALLUP, WA 98373;

Contractor: BUEHNER CONSTRUCTION INC 3158 S MAIN ST SALT LAKE CITY, UT 84115 (908) 448-7504

To construct: Commercial TI; into an existing space; Scope to include Mechanical, Electrical, Plumbing and 8-9' shelving display fixtures. XFINIITY

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide fire sprinkler cover approval prior to ceiling grid inspection.
 - 2 ; complete all ceiling grid requirements as discussed on last inspection.
- not ready

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org