



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Apr 02, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20240404

**Property Address:** 2902 E PIONEER, BUILDING G, PUYALLUP, WA

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902  
E PIONEER - APT BLDG G \* REVISION (1) - 1/30/2025 - ENGINEERED  
TRUSS DRAWINGS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; inspection of trusses in breezeways only. (complete truss bracing att wed at south trusses.
- 2 ; complete fire caulk at electrical penetration of densglass at breezeways.

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684