



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 02, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20241053

Property Address: 310 31ST AVE SE, PUYALLUP, WA 98374;

Contractor: SLETTEN CONSTRUCTION COMPANY PO BOX 2467 GREAT FALLS, MT 59403

To construct: General remodel to existing Walmart store. Interior updates include mechanical, electrical, plumbing, and cosmetic changes. Minor updates to exterior site. ~ WALMART INTERIOR REMODEL

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: approved test on plumbing at grab & go chace.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684