



City of Puyallup

## Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

STREAMLINE GENERAL CONSTRUCTION LLC  
1006 208TH AVE E  
LAKE TAPPS, WA 98391

April 04, 2025

### RE: INSPECTION PUNCHLIST FOR PERMIT PRCCP20241123

To Whom It May Concern:

City of Puyallup's Development Engineering has completed, at your request, a final inspection of the above referenced permit number.

The following is a list of outstanding items that must be completed prior to Engineering's final acceptance of the work. Please note that this list has been broken into two sections:

**Section A** are considered life/safety items that must be completed for the utilities to operate and be maintained as intended. **Therefore, Section A must be completed and accepted before Development Engineering can consider the project adequately complete and to allow issuance of an Occupancy Permit.**

**Section B** are punchlist items, and as such, do not have to be completed prior to occupancy. However, the items listed under Section B must be guaranteed to be completed within 90 days from the date of this letter. The City of Puyallup requires an assignment of funds in the amount of [AMOUNT NOT CALCULATED. CONTACT ENGINEERING REVIEWER.] to guarantee completion of the punchlist items.

#### **SECTION A**

(ITEMS WHICH MUST BE COMPLETED PRIOR TO OCCUPANCY)

#### **WATER:**

#### **SANITARY SEWER:**

#### **SIGNALIZATION:**

#### **STORM:**

- Please see permit condition #12. Work with COP review engineer and admin to resolve.  
#12 The stormwater infiltration trenches must be registered with Washington State Department of Ecology as UIC injection wells.

<https://ecology.wa.gov/regulations-permits/guidance-technical-assistance/underground-injection-control-program/register-uic-wells-online>

**STREET:**

**MISCELLANEOUS:**

## **SECTION B**

(ITEMS COVERED BY AN ASSIGNMENT OF FUNDS TO ALLOW OCCUPANCY)

**WATER:**

**SANITARY SEWER:**

**SIGNALIZATION:**

**STORM:**

**STREET:**

**MISCELLANEOUS:**

Upon completion of the items listed under Section B, the City will release the assignment of funds back to you. If any or all the items listed under Section B are not completed within 90 days of the date of this letter, the City has the right to use the funds being held to complete the remaining work.

After completion of the above work, please contact the project's Engineering Inspector, Jason Little, at (253) 244-0387 and schedule a punchlist inspection through the [CityView portal](#). If you have any questions regarding any of these items, please contact Jason Little or myself.

Sincerely,

Sam Morman  
Civil Engineer-Journey  
(253) 841-5411  
SMorman@PuyallupWA.gov

Cc: Jason Little, City of Puyallup Engineering Inspector  
Robin Loewen, DPS Support Specialist  
Robert Landa, Permit Holder